



OIL ANALYSIS REPORT

Area

RRJ
Machine Id

B-01-402 Biogas Blower Non-Drive End


Component

Non-Drive End Compressor

Fluid

GARDNER DENVER AEON PD (--- GAL)

Sample Rating Trend



WATER



DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil. There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		TWC0000004	WC0886364	WC0886374
Sample Date	Client Info		31 May 2024	02 May 2024	26 Mar 2024
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	SEVERE	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	36	▲ 135	▲ 51
Chromium	ppm	ASTM D5185m >10	2	10	4
Nickel	ppm	ASTM D5185m	0	<1	<1
Titanium	ppm	ASTM D5185m	0	<1	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	<1	2	3
Lead	ppm	ASTM D5185m >25	0	0	<1
Copper	ppm	ASTM D5185m >50	<1	<1	1
Tin	ppm	ASTM D5185m >15	<1	2	1
Vanadium	ppm	ASTM D5185m	0	0	<1
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	<1
Barium	ppm	ASTM D5185m	<1	0	0
Molybdenum	ppm	ASTM D5185m	3	<1	0
Manganese	ppm	ASTM D5185m	<1	1	<1
Magnesium	ppm	ASTM D5185m	0	<1	<1
Calcium	ppm	ASTM D5185m	2	4	5
Phosphorus	ppm	ASTM D5185m	654	663	631
Zinc	ppm	ASTM D5185m	3	9	4
Sulfur	ppm	ASTM D5185m	699	954	662

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	6	6	4
Sodium	ppm	ASTM D5185m	0	0	0
Potassium	ppm	ASTM D5185m >20	<1	<1	<1
Water	%	ASTM D6304 >0.1	▲ 0.206	▲ 2.49	▲ 0.534
ppm Water	ppm	ASTM D6304 >1000	▲ 2060	▲ 24900	▲ 5340

FLUID CLEANLINESS




	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	---	---	1740
Particles >6µm	ASTM D7647	>2500	---	---	948
Particles >14µm	ASTM D7647	>320	---	---	161
Particles >21µm	ASTM D7647	>80	---	---	54
Particles >38µm	ASTM D7647	>20	---	---	8
Particles >71µm	ASTM D7647	>4	---	---	1
Oil Cleanliness	ISO 4406 (c)	>20/18/15	---	---	18/17/15

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.51	0.57	0.63




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	● HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	0.2%
Free Water	scalar	*Visual		▲ 2.0	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 214	211	219	212

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TWC0000004 **Received** : 05 Jun 2024
Lab Number : 06200122 **Tested** : 07 Jun 2024
Unique Number : 11062245 **Diagnosed** : 07 Jun 2024 - Don Baldrige
Test Package : PLANT (Additional Tests: KF)

GEVO Inc.
 2498 250th Street
 Doon, IA
 US 51235
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: