




PROBLEM SUMMARY

Area **Effluent Treatment Plant** Machine Id Secondary Center Clarifier Top Gearbox 21-265-002.02 Top Gearbox

Fluid MOBIL SHC 636 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

| Sample Status | | | SEVERE | ATTENTION | |
|-----------------|--------------|-----------|-------------------|-----------|--|
| Particles >4µm | ASTM D7647 | >20000 | 🔺 123234 | | |
| Particles >6µm | ASTM D7647 | >5000 | 42927 | | |
| Particles >14µm | ASTM D7647 | >640 | <u> </u> | | |
| Particles >21µm | ASTM D7647 | >160 | 412 | | |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | 4 24/23/18 | | |


Customer Id: CASASH Sample No.: WC0776453 Lab Number: 06200132 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



| RECOMMENDED ACTIONS | | | | | | | |
|----------------------|--------|------|---------|--|--|--|--|
| Action | Status | Date | Done By | Description | | | |
| Change Filter | | | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. | | | |
| Resample | | | ? | Resample in 30-45 days to monitor this situation. | | | |
| Information Required | | | ? | NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. | | | |
| Check Breathers | | | ? | The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. | | | |
| Check Dirt Access | | | ? | We advise that you check all areas where contaminants can enter the system. | | | |
| Filter Fluid | | | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. | | | |

HISTORICAL DIAGNOSIS

26 Jan 2024 Diag: Jonathan Hester



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 460 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.





OIL ANALYSIS I

Particles >38µm

Particles >71µm

Oil Cleanliness

Acid Number (AN)

FLUID DEGRADATION

ASTM D7647 >40

ASTM D7647 >10

ISO 4406 (c)

mg KOH/g ASTM D8045

8

3

0.49

>21/19/16 🔺 24/23/18

Effluent Treatment Plant Secondary Center Clarifier Top Gearbox 21 **Top Gearbox**

MOBIL SHC 636 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

| SIS REP | ORT | | J | | | ISO |
|------------------------------|------------|----------------------------|-------------------|--------------------------|--------------------------|----------------|
| | | | | | | |
| | | | | | | |
| rbox 21-265- | იია სა | | | | | |
| | 002.02 | | | | | |
| | | | | ····· | | |
| | | | Jan2024 | Jun2024 | | |
| SAMPLE INFOF | | method | limit/base | e current | history1 | history2 |
| | | | iiiiii/base | | | |
| Sample Number Sample Date | | Client Info Client Info | | WC0776453 04 Jun 2024 | WC0776376 26 Jan 2024 | |
| Machine Age | hrs | Client Info | | 04 Juli 2024 0 | 20 Jan 2024 | |
| Oil Age | hrs | Client Info | | 0 | 0 | |
| Oil Changed | 1110 | Client Info | | 0 N/A | N/A | |
| Sample Status | | | | SEVERE | ATTENTION | |
| | | | line it /le e e e | | la ta ta mud | la i at a mu O |
| WEAR METALS |) | method | limit/base | | history1 | history2 |
| Iron | ppm | ASTM D5185m | >200 | 10 | 9 | |
| Chromium | ppm | ASTM D5185m | | 0 | 0 | |
| Nickel | ppm | ASTM D5185m | >15 | 0 | 0 | |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | |
| Silver | ppm | ASTM D5185m | 05 | 0 | 0 | |
| Aluminum | ppm | ASTM D5185m | >25 | 0 | <1 | |
| Lead | ppm | ASTM D5185m ASTM D5185m | >100 >200 | ں <1 | 0 <1 | |
| Copper Tin | ppm ppm | ASTM D5185m | >200 | <1 <1 | 0 | |
| Vanadium | ppm | ASTM D5185m | 220 | 0 | 0 | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | |
| | ppin | | | - | - | |
| ADDITIVES | | method | limit/base | e current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | |
| Barium | ppm | ASTM D5185m | | <1 | 0 | |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | |
| Magnesium | ppm | ASTM D5185m | | 0 | 0 | |
| Calcium | ppm | ASTM D5185m | | 2 | 2 | |
| Phosphorus | ppm | ASTM D5185m | | 470 | 437 | |
| Zinc | ppm | ASTM D5185m | | 0 | 0 59 | |
| Sulfur | ppm | ASTM D5185m | | 62 | | |
| CONTAMINANT | S | method | limit/base | e current | history1 | history2 |
| Silicon | ppm | | >50 | 21 | 28 | |
| Sodium | ppm | ASTM D5185m | | 0 | 0 | |
| Potassium | ppm | ASTM D5185m | >20 | 1 | <1 | |
| Water | % | ASTM D6304 | >0.2 | 0.004 | 0.004 | |
| ppm Water | ppm | ASTM D6304 | >2000 | 49 | 47 | |
| FLUID CLEANL | INESS | method | limit/base | e current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | >20000 | 🔺 123234 | | |
| Particles >6µm | | ASTM D7647 | >5000 | 42927 | | |
| Particles >14µm | | ASTM D7647 | >640 | A 2018 | | |
| Particles >21µm | | ASTM D7647 | >160 | <u> </u> | | |
| Deutiales 00 | | AOTH DZC 17 | 40 | • | | |


Sample Rating Trend

Submitted By: MARC-ANDRE HUBERT Page 3 of 4

0.43



OIL ANALYSIS REPORT



history1 NONE NONE NONE *Visual scalar *Visual NONE NONE NONE scalar NONE scalar *Visual NONE NONE scalar *Visual NONE NONE MODER *Visual NONE NONE NONE scalar NONE scalar *Visual NONE NONE NORML *Visual NORML NORML scalar *Visual NORML NORML scalar NORML *Visual scalar >0.2 NEG NFG scalar *Visual NEG NEG **FLUID PROPERTIES** limit/base history cSt ASTM D445 663.8 579 489.4 SAMPLE IMAGES no image no image Particle Count 491.5 122,880 30.72 7.68 Jun4/24 4406 per 1 1.920 Non-ferrous Metals 480 120 31 214 38L Acid Number (B),50 풍 0.40 Ē 0.30 · 문 0.20 0.10 Acid 0.00 un4/74 an 26 : WearCheck USA - 501 Madison Ave., Cary, NC 27513 CASCADES CONTAINERBOARD PACKAGING - BEARPACK PROJECT Received : 05 Jun 2024 10026 OLD RIDGE ROAD Tested : 06 Jun 2024 ASHLAND, VA Diagnosed : 06 Jun 2024 - Wes Davis US 23005 Contact: MARC-ANDRE HUBERT marc-andre_hubert@cascades.com

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: CASASH [WUSCAR] 06200132 (Generated: 06/07/2024 08:22:49) Rev: 1

Submitted By: MARC-ANDRE HUBERT

T:

F: