




PROBLEM SUMMARY

Area **Effluent Treatment Plant** Machine Id **Secondary East Clarifier Top Gearbox** 21-265-011.02 Top Gearbox

Fluid MOBIL SHC 636 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	
Particles >4µm	ASTM D7647	>20000	<u> </u>	▲ 167062	
Particles >6µm	ASTM D7647	>5000	47925	4 93118	
Particles >14µm	ASTM D7647	>640	4 5181	1 1654	
Particles >21µm	ASTM D7647	>160	1 541	2 715	
Oil Cleanliness	ISO 4406 (c)	>21/19/16	4 24/23/20	▲ 25/24/21	


Customer Id: CASASH Sample No.: WC0776451 Lab Number: 06200135 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Filter			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.			
Resample			?	Resample in 30-45 days to monitor this situation.			
Information Required			?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.			
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.			
Check Dirt Access			?	We advise that you check all areas where contaminants can enter the system.			
Filter Fluid			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.			

HISTORICAL DIAGNOSIS

26 Jan 2024 Diag: Wes Davis



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.





OIL ANALYSIS REPORT

Effluent Treatment Plant Machine Id **Secondary East Clarifier Top Gearbox** 21-265-011.02

Top Gearbox

MOBIL SHC 636 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.


Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORM		method	limit/base	current	history1	history2
Sample Number	AHON	Client Info	mmubase	WC0776451	WC0776372	THSIOLYZ
Sample Date		Client Info		04 Jun 2024	26 Jan 2024	
Machine Age	hrs	Client Info		04 Juli 2024	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed	1113	Client Info		N/A	N/A	
Sample Status				SEVERE	SEVERE	
WEAR METALS		method	limit/base	current	history1	history2
Iron	nom	ASTM D5185m	>200	25	24	
Chromium	ppm ppm	ASTM D5185m	>15	0	0	
Nickel	ppm	ASTM D5185m	>15	0	0	
Titanium	ppm	ASTM D5185m	210	0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	0	<1	
Lead	ppm	ASTM D5185m	>100	0	0	
Copper	ppm	ASTM D5185m	>200	<1	<1	
Tin	ppm	ASTM D5185m	>25	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
		ASTM D5185m	in the babb		0	
Boron Barium	ppm			0	0	
	ppm	ASTM D5185m ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0 <1	<1	
Manganese Magnesium	ppm ppm	ASTM D5185m		< 1 0	<1	
Calcium	ppm	ASTM D5185m		1	1	
Phosphorus	ppm	ASTM D5185m		472	439	
Zinc	ppm	ASTM D5185m		0	0	
Sulfur	ppm	ASTM D5185m		12	96	
CONTAMINANTS		method	limit/base			history
				current	history1	history2
Silicon	ppm	ASTM D5185m	>50	22	19	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	1	<1	
Water	%	ASTM D6304	>0.2	0.004	0.00	
ppm Water	ppm	ASTM D6304	>2000	41	0	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	<u> </u>	1 67062	
Particles >6µm		ASTM D7647		47925	4 93118	
Particles >14µm		ASTM D7647	>640	5181	▲ 11654	
Particles >21µm		ASTM D7647		1 541	▲ 2715	
Particles >38µm		ASTM D7647	>40	69	51	
Particles >71µm		ASTM D7647	>10	2	1	
Oil Cleanliness		ISO 4406 (c)	>21/19/16	4/23/20	▲ 25/24/21	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.42	0.35	



Sample Rating Trend

Submitted By: MARC-ANDRE HUBERT Page 3 of 4



OIL ANALYSIS REPORT

4μm	VISUAL		method	limit/base	current	history1	history2
ummana 6μm	White Metal	scalar	*Visual	NONE	NONE	NONE	
14μm	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
A.11.0 Million	Precipitate	scalar	*Visual	NONE	NONE	NONE	
	Silt	scalar	*Visual	NONE	NONE	NONE	
Abnormal	Debris	scalar	*Visual	NONE	NONE	NONE	
######################################	_ Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Jan 26/24	Appearance	scalar	*Visual	NORML	NORML	NORML	
L ar	Odor	scalar	*Visual	NORML	NORML	NORML	
Water (KF)	Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	
E	Free Water	scalar	*Visual		NEG	NEG	
Severe	FLUID PROPER	RTIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	663.8	677	674	
	SAMPLE IMAGI	ES	method	limit/base	current	history1	history2
Abnormal		20	method	in in base			motoryz
an 26/24	Color				a		no image
Jan26/24							
Acid Number							
	Bottom				62)		no image
	GRAPHS						
	Ferrous Alloys				Particle Coun	t	
				- 491,520			T ²
	20 - iron chromium			122,880	Severe		
Jan 26/24	E 15 10			122,000	and a second		-2
L an	⁻ 10-			30,720	Abnormal		-2
Water (KF)	5			7,680			-2
	5/2 4		*********************			1	2
Severe	Jan 26/24			Jun4/24 (per 1 ml)	1		-11
	Non-ferrous Met	als		·문 480		· \	
	¹⁰ T			of ba			
	8 - copper			ja 120	-		-11
Abnormal	E 6			2 30	-		
	₽ 4 .						
Jan 26/24	2						
С ani	5/24			4/24			8
Viscosity @ 40°C	Jan26/2 [,]			Jun4/			
	Viscosity @ 40°C	C		l.	Acid Number	14μ 21μ	38µ 71µ
	750 Abnormal			0.50			
Base	700 - Base			0.50 Hoy 0.40			
	30 650 - 650 -			Ĕ 0.30			
	Ab I			-a g 0.20			
Abnormal	550 - Abnormal			N 0.10			
	500 4			U.UL	24+0		
lan 26/24	Jan 26/2			Jun4/24	Jan 26/24		
Jani	5				-i		
Laboratory	b. : WC0776451	Recei	ved : 05	5 Jun 2024	CASCADES	CONTAINERBOARD PACKAGIN 10026 OLD	RIDGE RC
	er : 06200135	Teste		7 Jun 2024	laa Davis	1	ASHLAND, Y
	per : 11062258	Diagr	iosed : 07	' Jun 2024 - W		ntact: MARC-AN	US 230
Teat Dealer						maci, ivianu-ani	
Certificate L2367 Test Packag		rvice at 1-8	00-237-136	7		-andre_hubert@	

Report Id: CASASH [WUSCAR] 06200135 (Generated: 06/07/2024 23:23:29) Rev: 1

Submitted By: MARC-ANDRE HUBERT

Page 4 of 4