




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
TK1 HOMO 1 EAST (S/N J3-20.122)
 Component
Refrigeration Compressor
 Fluid
LUBRIPLATE SFGO ULTRA 100 (--- GAL)

DIAGNOSIS

▲ Recommendation

Resample at the next service interval to monitor.

▲ Wear

The iron level is abnormal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|----------|
| Sample Number | Client Info | | USP217908 | USP0011866 | --- |
| Sample Date | Client Info | | 25 May 2024 | 12 May 2024 | --- |
| Machine Age | hrs | Client Info | 0 | 0 | --- |
| Oil Age | hrs | Client Info | 0 | 0 | --- |
| Oil Changed | Client Info | | N/A | N/A | --- |
| Sample Status | | | MARGINAL | ABNORMAL | --- |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|----------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m >8 | ▲ 36 | ▲ 58 | --- |
| Chromium | ppm | ASTM D5185m >2 | 0 | <1 | --- |
| Nickel | ppm | ASTM D5185m | 0 | <1 | --- |
| Titanium | ppm | ASTM D5185m | 0 | <1 | --- |
| Silver | ppm | ASTM D5185m >2 | 0 | <1 | --- |
| Aluminum | ppm | ASTM D5185m >3 | 1 | 2 | --- |
| Lead | ppm | ASTM D5185m >2 | <1 | 2 | --- |
| Copper | ppm | ASTM D5185m >8 | 2 | 3 | --- |
| Tin | ppm | ASTM D5185m >4 | 2 | 3 | --- |
| Vanadium | ppm | ASTM D5185m | 0 | <1 | --- |
| Cadmium | ppm | ASTM D5185m | 0 | <1 | --- |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | 0 | 0 | --- |
| Barium | ppm | ASTM D5185m | 0 | 0 | --- |
| Molybdenum | ppm | ASTM D5185m | 0 | <1 | --- |
| Manganese | ppm | ASTM D5185m | <1 | 0 | --- |
| Magnesium | ppm | ASTM D5185m | 0 | <1 | --- |
| Calcium | ppm | ASTM D5185m | <1 | <1 | --- |
| Phosphorus | ppm | ASTM D5185m | 653 | 652 | --- |
| Zinc | ppm | ASTM D5185m | 0 | 0 | --- |
| Sulfur | ppm | ASTM D5185m | 1841 | 1900 | --- |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >15 | 1 | 2 | --- |
| Sodium | ppm | ASTM D5185m | <1 | 1 | --- |
| Potassium | ppm | ASTM D5185m >20 | 1 | 1 | --- |
| Water | % | ASTM D6304 >0.01 | 0.002 | ▲ 0.015 | --- |
| ppm Water | ppm | ASTM D6304 >100 | 19 | ▲ 157 | --- |

FLUID CLEANLINESS






| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-----------------|------------|----------|
| Particles >4µm | ASTM D7647 | >10000 | 2320 | ▲ 152590 | --- |
| Particles >6µm | ASTM D7647 | >2500 | 319 | ▲ 69513 | --- |
| Particles >14µm | ASTM D7647 | >640 | 13 | ▲ 990 | --- |
| Particles >21µm | ASTM D7647 | >160 | 5 | 106 | --- |
| Particles >38µm | ASTM D7647 | >40 | 2 | 2 | --- |
| Particles >71µm | ASTM D7647 | >10 | 0 | 0 | --- |
| Oil Cleanliness | ISO 4406 (c) | >20/18/16 | 18/15/11 | ▲ 24/23/17 | --- |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D974 | 0.18 | 0.17 | --- |



OIL ANALYSIS REPORT








| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | --- |
| Yellow Metal | scalar | *Visual | NONE | NONE | --- |
| Precipitate | scalar | *Visual | NONE | NONE | --- |
| Silt | scalar | *Visual | NONE | NONE | --- |
| Debris | scalar | *Visual | NONE | NONE | --- |
| Sand/Dirt | scalar | *Visual | NONE | NONE | --- |
| Appearance | scalar | *Visual | NORML | NORML | --- |
| Odor | scalar | *Visual | NORML | NORML | --- |
| Emulsified Water | scalar | *Visual | >0.01 | NEG | --- |
| Free Water | scalar | *Visual | | NEG | --- |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 98 | 94.6 | 96.1 | --- |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP217908
Lab Number : 06200143
Unique Number : 11062266
Test Package : IND 2

KraftHeinz - Champaign - Plant 8318
 702 N MATTHIS AVE, DOOR 22 EAST STOREROOM
 CHAMPAIGN, IL
 US 61821
 Contact: Nathan Shankles
 Nathan.Shankles@kraftheinz.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)