




PROBLEM SUMMARY


Area
PHS AND PLS SYSTEM
 Machine Id
RECYCLED NH3 SYSTEM 1
 Component
Refrigeration Compressor
 Fluid
USPI ALT-68 SC (--- GAL)

Sample Rating Trend




COMPONENT CONDITION SUMMARY

▲ Water (KF)



▲ Ferrous Alloys



RECOMMENDATION

This is a baseline read-out on the submitted sample. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We were unable to perform a particle count due to a high concentration of particles present in this sample. System 1 Before

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	NORMAL	ABNORMAL
Iron	ppm	ASTM D5185m	>8	▲ 187	4	▲ 137
Water	%	ASTM D6304	>0.01	▲ 0.472	0.003	0.009
ppm Water	ppm	ASTM D6304	>100	▲ 4720	27	93
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Emulsified Water	scalar	*Visual	>0.01	▲ 0.2%	NEG	NEG
Free Water	scalar	*Visual		▲ >10%	NEG	NEG

Customer Id: SMITAR
 Sample No.: USP0012557
 Lab Number: 06200228
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

NORMAL



30 Apr 2024 Diag: Doug Bogart

This is a baseline read-out on the submitted sample. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



WEAR



15 Apr 2024 Diag: Doug Bogart

This is a baseline read-out on the submitted sample. The iron level is abnormal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



NORMAL



14 Mar 2024 Diag: Doug Bogart

This is a baseline read-out on the submitted sample. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



Area
PHS AND PLS SYSTEM
 Machine Id
RECYCLED NH3 SYSTEM 1
 Component
Refrigeration Compressor
 Fluid
USPI ALT-68 SC (--- GAL)

DIAGNOSIS

▲ Recommendation

This is a baseline read-out on the submitted sample. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We were unable to perform a particle count due to a high concentration of particles present in this sample. System 1 Before

▲ Wear

The iron level is severe.

▲ Contamination

Excessive free water present. There is a high concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		USP0012557	USP0011126	USP0006454
Sample Date	Client Info		03 Jun 2024	30 Apr 2024	15 Apr 2024
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	NORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	▲ 187	4	▲ 137
Chromium	ppm	ASTM D5185m >2	<1	0	0
Nickel	ppm	ASTM D5185m	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >3	0	0	0
Lead	ppm	ASTM D5185m >2	0	0	0
Copper	ppm	ASTM D5185m >8	0	0	0
Tin	ppm	ASTM D5185m >4	0	0	0
Vanadium	ppm	ASTM D5185m	0	0	<1
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m	<1	0	0
Calcium	ppm	ASTM D5185m	0	0	0
Phosphorus	ppm	ASTM D5185m	<1	0	<1
Zinc	ppm	ASTM D5185m	6	0	0
Sulfur	ppm	ASTM D5185m 50	0	10	0

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	2	2	2
Sodium	ppm	ASTM D5185m	<1	<1	<1
Potassium	ppm	ASTM D5185m >20	0	0	0
Water	%	ASTM D6304 >0.01	▲ 0.472	0.003	0.009
ppm Water	ppm	ASTM D6304 >100	▲ 4720	27	93

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	---	932	▲ 219532
Particles >6µm	ASTM D7647	>2500	---	87	▲ 153393
Particles >14µm	ASTM D7647	>320	---	7	▲ 7003
Particles >21µm	ASTM D7647	>80	---	2	▲ 237
Particles >38µm	ASTM D7647	>20	---	0	0
Particles >71µm	ASTM D7647	>4	---	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	---	17/14/10	▲ 25/24/20

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974 0.005	0.066	0.014	0.069

