


PROBLEM SUMMARY





PHS AND PLS SYSTEM RECYCLED NH3 SYSTEM 2

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

This is a baseline read-out on the submitted sample. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We were unable to perform a particle count due to a high concentration of particles present in this sample. System 2 before

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE	NORMAL	ABNORMAL		
Iron	ppm	ASTM D5185m	>8	▲ 312	4	▲ 136		
Water	%	ASTM D6304	>0.01	▲ 0.717	0.004	0.006		
ppm Water	ppm	ASTM D6304	>100	17170	42	62		
Silt	scalar	*Visual	NONE	MODER	NONE	NONE		
Emulsified Water	scalar	*Visual	>0.01	0.2%	NEG	NEG		
Free Water	scalar	*Visual		▲ >10%	NEG	NEG		

Customer Id: SMITAR Sample No.: USP0012556 Lab Number: 06200229 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.		
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.		

HISTORICAL DIAGNOSIS

30 Apr 2024 Diag: Doug Bogart

This is a baseline read-out on the submitted sample. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



WEAR

15 Apr 2024 Diag: Doug Bogart


This is a baseline read-out on the submitted sample. The iron level is abnormal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



.

14 Mar 2024 Diag: Doug Bogart

NORMAL










OIL ANALYSIS REPORT

PHS AND PLS SYSTEM **RECYCLED NH3 SYSTEM 2**

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)



DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample. We advise that you follow the water drainoff procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We were unable to perform a particle count due to a high concentration of particles present in this sample. System 2 before

The iron level is severe.

Contamination

Excessive free water present. There is a high concentration of water present in the oil. There is a moderate amount of visible silt present in the sample.


Fluid Condition


The AN level is acceptable for this fluid.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info	- mmbaasc	USP0012556	USP0011127	USP0006453
Sample Date		Client Info		03 Jun 2024	30 Apr 2024	15 Apr 2024
Machine Age	hrs	Client Info		03 0411 2024	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	1113	Client Info		N/A	N/A	N/A
Sample Status		Ollerit IIIIO		SEVERE	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	▲ 312	4	<u> 136</u>
Chromium	ppm	ASTM D5185m	>2	1	0	0
Nickel	ppm	ASTM D5185m	/ _	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m	77	0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES	le le	method	limit/base	current	history1	history2
Boron	nnm	ASTM D5185m	mmobase	0	0	0
Barium	ppm	ASTM D5185m		0	0	0
	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		∪ <1	0	<1
Manganese Magnesium	ppm	ASTM D5185m		<1	0	<1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		<1	0	1
Zinc	ppm	ASTM D5185m		9	0	0
Sulfur	ppm	ASTM D5185m	50	0	105	0
	ppm			-		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	2	2
Sodium	ppm	ASTM D5185m		<1	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304		▲ 0.717	0.004	0.006
ppm Water	ppm	ASTM D6304	>100	▲ 7170	42	62
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000		918	<u>^</u> 245091
Particles >6µm		ASTM D7647			124	<u>▲</u> 166019
Particles >14μm		ASTM D7647	>320		9	<u>▲</u> 5878
Particles >21μm		ASTM D7647			2	<u>▲</u> 153
Particles >38μm		ASTM D7647	>20		0	0
Particles >71μm		ASTM D7647			0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15		17/14/10	<u>\$\text{\Delta}\$ 25/25/20</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.098	0.025	0.083




OIL ANALYSIS REPORT









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	HAZY
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	0.2%	NEG	NEG
Free Water	scalar	*Visual		▲ >10%	NEG	NEG


FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	65.6	65.1	65.2	65.0


Color







GRAPHS













Certificate 12367

Laboratory Sample No.

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : USP0012556 Lab Number : 06200229

Unique Number : 11062352

Received **Tested**

: 05 Jun 2024 : 10 Jun 2024

Diagnosed : 10 Jun 2024 - Jonathan Hester **SMITHFIELD FOOD - TARHEEL**

15855 HWY. 87 WEST TARHEEL, NC US 28392

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: