

OIL ANALYSIS REPORT



Machine Id

Component Diesel Engine Fluid MOBIL MOBILGARD 412 (--- GAL)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition

The oil viscosity is lower than normal. The BN result indicates that there is suitable alkalinity remaining in the oil.

	ATION	methou	IIIIII/Dase	current	HISTOLA	TIIStory2
Sample Number		Client Info		RP0043308	RP0039440	RP0038817
Sample Date		Client Info		04 Jun 2024	13 Mar 2024	11 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				MARGINAL	ABNORMAL	NORMAI
Campie Claus				MARGINAL	ADITOTIMAL	NOTIVIAL
CONTAMINATION	١	method	limit/base	current	history1	history2
Glycol		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	2	0	0
Chromium	ppm	ASTM D5185m	>20	0	<1	0
Nickel	ppm	ASTM D5185m	>4	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	maa	ASTM D5185m	>3	0	0	0
Aluminum	maa	ASTM D5185m	>20	<1	<1	<1
Lead	ppm	ASTM D5185m	>40	0	<1	0
Copper	ppm	ASTM D5185m	>330	۔ د1	1	0
Tin	ppm	ASTM D5185m	>15	0	<1	0
Vanadium	nnm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
Guaiman	ppm			Ũ	~ 1	Ũ
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	3	1	<1
Barium	ppm	ASTM D5185m	0	2	0	0
Molybdenum	ppm	ASTM D5185m	0	2	0	0
Manganese	ppm	ASTM D5185m	0	<1	<1	<1
Magnesium	ppm	ASTM D5185m	18	18	9	17
Calcium	ppm	ASTM D5185m	6350	4701	4982	5390
Phosphorus	ppm	ASTM D5185m	200	168	203	205
Zinc	ppm	ASTM D5185m	380	357	381	357
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	6	8	8
Sodium	ppm	ASTM D5185m		<1	3	2
Potassium	maa	ASTM D5185m	>20	0	0	0
Fuel	%	ASTM D3524	>5	1.6	1.6	<1.0
Water	%	ASTM D6304	>0.2	NEG	0.829	NEG
ppm Water	mag	ASTM D6304	>2000		▲ 8290	
	le le				lainte mut	history O
INFRA-RED		method	limit/base	current	nistory i	nistory2
Soot %	%	*ASTM D7844	>3	0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	5.1	6.7	7.4
Sulfation	Abs/.1mm	*ASTM D7415	>30	12.1	10.3	9.6
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	2.8	3.3	3.8
Base Number (BN)	mg KOH/a	ASTM D2896	15	12.27	13.12	14.97
	0.000					



OIL ANALYSIS REPORT

scalar

scalar

scalar

scalar

scalar

scalar

scalar

scalar

method

*Visual

*Visual

*Visual

*Visual

*Visual

*Visual

*Visual

*Visual

method

scalar *Visual

scalar *Visual

limit/base

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

limit/base

>0.2

current

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

current

NEG

NEG

history1

NONE

NONE

NONE

NONE

NONE

NONE

MILKY

NORM

0.2%

NEG

history

history2

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

history2

NEG

NEG

VISUAL

White Metal

Yellow Metal

Precipitate

Silt

Debris

Odor

Sand/Dirt

Appearance

Free Water

Emulsified Water

FLUID PROPERTIES









Viscosity @ 40°C 160 155 150 () 14! 200 14! 20 135 130 Abnorma 12 Jun4/24 Sep 12/23 Dec11/19 Mar4/1 CIACan



	Visc @ 100°C	cSt	ASTM D445	14.5	<u> </u>	7.59	14.1
~	GRAPHS						
Sep12/23	Ferrous Alloys	$\sum_{i=1}^{n}$	1	1			
- \	Mar4/19	Aug1/21 May29/22	Jan 16/23	Jun4/24			
E #	Non-ferrous Me	tals					
Sep12/7 Jun4/2	25 - copper lead	A					

C/ (10 Mard Decl Viscosity @ 100°C Acid Number 20 1.40 18 1.20 10 (B/HO) 00 B cSt (100°C) Ê 0.80 ₩ Ê 0.60 10 응 0.40

Sep12/23

Jan 16/23

Jun4/24

Aug1/21.

/av29/22

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Jan24/21

Dec11/19

Mar4/19

Laboratory



Sample No. : RP0043308 Received : 05 Jun 2024 474 BROOKLINE AVE Tested : 10 Jun 2024 Lab Number : 06200349 BOSTON, MA Unique Number : 11062472 Diagnosed : 10 Jun 2024 - Jonathan Hester US 02215 Test Package : IND 2 (Additional Tests: FT-IR, FuelDilution, KV100, PercentFuel, TBM/http://www.additional.com/ To discuss this sample report, contact Customer Service at 1-800-237-1369. robert.stsauveur@engie.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (401)651-9381 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) E:

Report Id: ENGBOS [WUSCAR] 06200349 (Generated: 06/10/2024 15:20:16) Rev: 1

Certificate 12367

Contact/Location: ROBERT ST SAUVEUR - ENGBOS

Page 2 of 2

ENGIE-MATEP