




OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
KAESER SFC 30ST 4358855 (S/N 1007)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KC98737	KCPA015025	KC98736
Sample Date	Client Info			30 May 2024	26 Mar 2024	14 Dec 2023
Machine Age	hrs	Client Info		98862	97566	95639
Oil Age	hrs	Client Info		769	2000	2008
Oil Changed	Client Info			Not Changed	Not Changd	Not Changed
Sample Status				ABNORMAL	ATTENTION	ATTENTION

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	11	1	0
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	<1	<1	<1
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	0	2	0
Lead	ppm	ASTM D5185m	>10	<1	<1	0
Copper	ppm	ASTM D5185m	>50	3	3	2
Tin	ppm	ASTM D5185m	>10	<1	1	<1
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	31	22
Molybdenum	ppm	ASTM D5185m		<1	1	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	90	27	46	29
Calcium	ppm	ASTM D5185m	2	17	5	0
Phosphorus	ppm	ASTM D5185m		20	6	0
Zinc	ppm	ASTM D5185m		30	6	0

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		8	24	20
Potassium	ppm	ASTM D5185m	>20	2	11	4
Water	%	ASTM D6304	>0.05	0.009	0.013	0.015
ppm Water	ppm	ASTM D6304	>500	95	136	156

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4615	5334	8260
Particles >6µm		ASTM D7647	>1300	▲ 1811	1217	● 2419
Particles >14µm		ASTM D7647	>80	▲ 251	● 97	● 119
Particles >21µm		ASTM D7647	>20	▲ 75	20	● 25
Particles >38µm		ASTM D7647	>4	3	0	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ 19/18/15	● 20/17/14	● 20/18/14

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.34	0.37	0.33

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.7	46.4	44.5

SAMPLE IMAGES

method	limit/base	current	history1	history2
Color				
Bottom				

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC98737 **Received** : 05 Jun 2024
Lab Number : 06200743 **Tested** : 06 Jun 2024
Unique Number : 11062866 **Diagnosed** : 07 Jun 2024 - Don Baldrige
Test Package : IND 2

GC HANFORD MFG
 304 ONEIDA ST
 SYRACUSE, NY
 US 13201
 Contact: J FLEMING
 JFLEMING@HANFORD.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)