

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 7737031

Component Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC129001	KC102641	
Sample Date		Client Info		24 May 2024	02 Mar 2023	
Machine Age	hrs	Client Info		0	1170	
Oil Age	hrs	Client Info		2000	1169	
Oil Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	5	2	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	0	40	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		0	0	
Zinc	ppm	ASTM D5185m		0	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	
Sodium	ppm	ASTM D5185m		2	11	
Potassium	ppm	ASTM D5185m	>20	<1	5	
Water	%	ASTM D6304	>0.05	0.007	0.019	
ppm Water	ppm	ASTM D6304	>500	78	190.2	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		239	4092	
Particles >6µm		ASTM D7647	>1300	109	2484	
Particles >14µm		ASTM D7647	>80	14	424	
Particles >21µm		ASTM D7647	>20	7	A 84	
Particles >38µm		ASTM D7647	>4	0	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	15/14/11	▲ 19/18/16	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.41	0.37	



OIL ANALYSIS REPORT





VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	
FLUID PROPER	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.3	43.9	
SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Color				a.		no image
Bottom						no image
GRAPHS						
Ferrous Alloys				Particle Count	t	
o iron			491,520	I		T ²
o - chromium			122,880	-		-2
6			00.700			
2			30,720	1		-2
0			7,680	- N.		
Mar2/23			May24/24 s (per 1 ml)			
м М			1,920 ss (per 1	1 × 1	N	
Non-ferrous Meta	ls		May24/24 May24/24 150 150 150 150 150 150 150 150 150 150	·		
			r of p			
8 - seeseeseeseeseeseeseeseeseeseeseeseesee					N	Ī
6 tin			30			
4						
2				Seven emal	1	
			1/24			
Mar2/23			May24/24			
Viscosity @ 40°C			≥ 0	4μ 6μ	14µ 21µ	38µ 71
⁵ T			- 0.50	Acid Number		
Abnormal				Base		
Base						
5 - Abnormal			(0,50 0)H0 0.40 JH0 J B0U 0.30 aquin 0.20 V 0.10 V 0.10			
			P 0.10			
5			0.00			
2			May24/24	Mar2/23		
Mar2/23			2	1 <u></u>		

SOUTHERN PAINT AND POWDER COATING



To discuss this sample report, contact Customer Service at 1-800-237-1369.

: KC129001

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received

Diagnosed

Tested

: 05 Jun 2024

: 06 Jun 2024

: 07 Jun 2024 - Don Baldridge

T: F:

Certificate 12367

Laboratory

Sample No.

Lab Number : 06200761

Unique Number : 11062884

Test Package : IND 2

Contact/Location: Service Manager - SOUPAG