




FUEL REPORT

Sample Rating Trend



NORMAL



Area
[PMOAS3139178]

Machine Id
174947

Component
Diesel Fuel

Fluid
No.2 DIESEL FUEL (HIGH-SULPHUR) (--- GAL)

DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			DC0036994	DC0029057	DC0019533
Sample Date	Client Info			20 May 2024	18 Apr 2023	20 Apr 2022
Machine Age	hrs	Client Info		1169	1132	1102
Sample Status				NORMAL	NORMAL	NORMAL

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		L5.0	L4.5	L5.5
Visc @ 40°C	cSt	ASTM D445	3.0	2.67	2.59	2.64

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	500	891	421	702
Sulfur (UVF)	ppm	ASTM D5453		885	683	689

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	34.9	34.9	34.9



CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1	0	4
Sodium	ppm	ASTM D5185m	<0.1	1	<1	0
Potassium	ppm	ASTM D5185m	<0.1	2	0	<1
Water	%	ASTM D6304	<0.05	0.003	0.004	0.002
ppm Water	ppm	ASTM D6304	<500	31	42.7	19.8
% Gasoline	%	*In-House	<0.50	0.0	0.0	0.0
% Biodiesel	%	*In-House	<20.0	0.0	0.0	0.0

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	---	1671	3001
Particles >6µm		ASTM D7647	>640	---	624	787
Particles >14µm		ASTM D7647	>80	---	68	74
Particles >21µm		ASTM D7647	>20	---	20	18
Particles >38µm		ASTM D7647	>4	---	0	2
Particles >71µm		ASTM D7647	>3	---	0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	---	18/16/13	19/17/13

HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	<1	<1
Nickel	ppm	ASTM D5185m	<0.1	0	0	0
Lead	ppm	ASTM D5185m	<0.1	0	0	<1
Vanadium	ppm	ASTM D5185m	<0.1	0	0	0
Iron	ppm	ASTM D5185m	<0.1	0	0	0
Calcium	ppm	ASTM D5185m	<0.1	<1	0	0
Magnesium	ppm	ASTM D5185m	<0.1	0	<1	0
Phosphorus	ppm	ASTM D5185m	<0.1	<1	0	0
Zinc	ppm	ASTM D5185m	<0.1	0	0	0




FUEL REPORT



SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0036994 **Received** : 05 Jun 2024
Lab Number : 06201099 **Tested** : 13 Jun 2024
Unique Number : 11063222 **Diagnosed** : 13 Jun 2024 - Doug Bogart
Test Package : DF-5 (Additional Tests: API, Cetane, Fuel, PrtCount, Screen)

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736
 Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)