




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
HOWARD SHEPPARD
 Machine Id
2563 HOWARD SHEPPARD
 Component
Front Differential
 Fluid
{not provided} (--- GAL)

DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

▲ Wear

Gear wear is indicated.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0934569	WC0934577	WC0771233
Sample Date	Client Info		14 Apr 2024	12 Apr 2024	15 Oct 2022
Machine Age	mls	Client Info	189581	189671	38877
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >500	▲ 846	▲ 791	319
Chromium	ppm	ASTM D5185m >10	5	5	2
Nickel	ppm	ASTM D5185m >10	1	1	0
Titanium	ppm	ASTM D5185m	<1	<1	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	10	9	3
Lead	ppm	ASTM D5185m >25	<1	<1	0
Copper	ppm	ASTM D5185m >100	3	3	1
Tin	ppm	ASTM D5185m >10	0	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	109	100	109
Barium	ppm	ASTM D5185m	2	2	0
Molybdenum	ppm	ASTM D5185m	<1	<1	<1
Manganese	ppm	ASTM D5185m	21	19	11
Magnesium	ppm	ASTM D5185m	168	150	148
Calcium	ppm	ASTM D5185m	4	2	2
Phosphorus	ppm	ASTM D5185m	1662	1597	1540
Zinc	ppm	ASTM D5185m	16	13	4
Sulfur	ppm	ASTM D5185m	23807	24011	26361

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >75	43	41	14
Sodium	ppm	ASTM D5185m	7	6	4
Potassium	ppm	ASTM D5185m >20	2	2	0
Water	%	ASTM D6304 >.2	0.141	0.010	0.035
ppm Water	ppm	ASTM D6304 >2000	1410	102	358.0

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	5664	▲ 206090	▲ 195904
Particles >6µm	ASTM D7647	>5000	3085	▲ 148045	▲ 122816
Particles >14µm	ASTM D7647	>640	525	▲ 2596	▲ 1713
Particles >21µm	ASTM D7647	>160	177	29	54
Particles >38µm	ASTM D7647	>40	27	1	2
Particles >71µm	ASTM D7647	>10	3	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	20/19/16	▲ 25/24/19	▲ 25/24/18

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.80	0.90	0.76




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.2	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	55.8	56.4	58.3
Visc @ 100°C	cSt	ASTM D445	10.0	10.0	10.5
Viscosity Index (VI)	Scale	ASTM D2270	167	165	171

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0934569 **Received** : 06 Jun 2024
Lab Number : 06201492 **Tested** : 13 Jun 2024
Unique Number : 11063615 **Diagnosed** : 17 Jun 2024 - Doug Bogart
Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCount, VI)

BASF - GIANNA CREDAROLI
 500 WHITE PLAINS RD
 TARRYTOWN, NY
 US 10591
 Contact: MIKE BARRY
 mike.barry@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)