




# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Area  
**HOWARD SHEPPARD**  
 Machine Id  
**2610 HOWARD SHEPPARD**  
 Component  
**Rear Differential**  
 Fluid  
**GEAR OIL SAE 80 (--- GAL)**

### DIAGNOSIS

#### ▲ Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0934578</b>	WC0771215	---
Sample Date	Client Info			<b>12 Apr 2024</b>	12 Aug 2022	---
Machine Age	mls	Client Info		<b>173135</b>	350	---
Oil Age	mls	Client Info		<b>0</b>	0	---
Oil Changed	Client Info			<b>N/A</b>	N/A	---
Sample Status				<b>ABNORMAL</b>	NORMAL	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>500	<b>229</b>	2	---
Chromium	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	---
Nickel	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	---
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0	---
Silver	ppm	ASTM D5185m		<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m	>25	<b>8</b>	<1	---
Lead	ppm	ASTM D5185m	>25	<b>&lt;1</b>	<1	---
Copper	ppm	ASTM D5185m	>100	<b>1</b>	0	---
Tin	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	---
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	---
Cadmium	ppm	ASTM D5185m		<b>&lt;1</b>	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	400	<b>280</b>	290	---
Barium	ppm	ASTM D5185m	200	<b>&lt;1</b>	0	---
Molybdenum	ppm	ASTM D5185m	12	<b>&lt;1</b>	0	---
Manganese	ppm	ASTM D5185m		<b>5</b>	<1	---
Magnesium	ppm	ASTM D5185m	12	<b>14</b>	<1	---
Calcium	ppm	ASTM D5185m	150	<b>&lt;1</b>	<1	---
Phosphorus	ppm	ASTM D5185m	1650	<b>1397</b>	1492	---
Zinc	ppm	ASTM D5185m	125	<b>10</b>	2	---
Sulfur	ppm	ASTM D5185m	22500	<b>23582</b>	27283	---






CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>75	<b>29</b>	1	---
Sodium	ppm	ASTM D5185m		<b>3</b>	<1	---
Potassium	ppm	ASTM D5185m	>20	<b>2</b>	<1	---
Water	%	ASTM D6304	>.2	<b>0.018</b>	0.070	---
ppm Water	ppm	ASTM D6304	>2000	<b>189</b>	709.1	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	▲ <b>197640</b>	14147	---
Particles >6µm		ASTM D7647	>5000	▲ <b>115530</b>	3433	---
Particles >14µm		ASTM D7647	>640	▲ <b>6492</b>	123	---
Particles >21µm		ASTM D7647	>160	▲ <b>1032</b>	25	---
Particles >38µm		ASTM D7647	>40	<b>14</b>	1	---
Particles >71µm		ASTM D7647	>10	<b>1</b>	0	---
Oil Cleanliness		ISO 4406 (c)	>21/19/16	▲ <b>25/24/20</b>	21/19/14	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	2.00	<b>1.99</b>	2.36	---



# OIL ANALYSIS REPORT




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>.2	NEG	---
Free Water	scalar	*Visual		NEG	---


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	74	60.3	53.6
Visc @ 100°C	cSt	ASTM D445	9.0	10.6	9.9
Viscosity Index (VI)	Scale	ASTM D2270	94	167	173

### SAMPLE IMAGES


SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					




no image



no image






no image



no image

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0934578      **Received** : 06 Jun 2024  
**Lab Number** : 06201496      **Tested** : 07 Jun 2024  
**Unique Number** : 11063619      **Diagnosed** : 11 Jun 2024 - Jonathan Hester  
**Test Package** : MOB 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**BASF - GIANNA CREDAROLI**  
 500 WHITE PLAINS RD  
 TARRYTOWN, NY  
 US 10591  
 Contact: MIKE BARRY  
 mike.barry@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)