

OIL ANALYSIS REPORT

Sample Rating Trend ISO

Machine Id

KAESER AIRCENTER SX 5 9283832 (S/N 1872)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
			111111111111111111111111111111111111111		,	
Sample Number		Client Info		KCPA017942		
Sample Date	lawa	Client Info		14 May 2024		
Machine Age	hrs	Client Info		4173		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed ABNORMAL		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	2		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m	>50	4		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	19		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	30		
Calcium	ppm	ASTM D5185m	2	<1		
Phosphorus	ppm	ASTM D5185m		14		
Zinc	ppm	ASTM D5185m		10		
Sulfur	ppm	ASTM D5185m		19097		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		5		
Potassium	ppm	ASTM D5185m	>20	8		
Water	%	ASTM D6304	>0.05	0.014		
ppm Water	ppm	ASTM D6304	>500	141		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		56588		
Particles >6µm		ASTM D7647	>1300	△ 33606		
Particles >14µm		ASTM D7647	>80	▲ 3670		
Particles >21µm		ASTM D7647	>20	462		
Particles >38µm		ASTM D7647	>4	<u>^</u> 8		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>23/22/19</u>		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.32		



OIL ANALYSIS REPORT




Tested

Diagnosed

: 07 Jun 2024

: 09 Jun 2024 - Don Baldridge



Certificate 12367

Lab Number

Unique Number: 11063637

: 06201514

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Test Package : IND 2 (Additional Tests: KF, PrtCount)

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

LEITCHFIELD, KY

Contact: T. TICHENOR

ttichenor@baillie.com

US 42754

T:

F: