




# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**KAESER 6838413 (S/N 1032)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

Oil and filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We recommend an early resample in 500 hours to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KCPA014668</b>	KCPA001423	KCP39026
Sample Date	Client Info	<b>16 May 2024</b>	15 Mar 2023	05 Nov 2021
Machine Age	hrs	Client Info	11906	4580
Oil Age	hrs	Client Info	0	2300
Oil Changed	Client Info	<b>Changed</b>	N/A	Not Changd
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >50	<b>2</b>	1	<1
Chromium	ppm ASTM D5185m >10	<b>&lt;1</b>	0	0
Nickel	ppm ASTM D5185m >3	<b>0</b>	0	0
Titanium	ppm ASTM D5185m >3	<b>&lt;1</b>	0	0
Silver	ppm ASTM D5185m >2	<b>0</b>	0	<1
Aluminum	ppm ASTM D5185m >10	<b>2</b>	<1	0
Lead	ppm ASTM D5185m >10	<b>&lt;1</b>	<1	<1
Copper	ppm ASTM D5185m >50	<b>5</b>	23	2
Tin	ppm ASTM D5185m >10	<b>&lt;1</b>	0	0
Antimony	ppm ASTM D5185m	<b>---</b>	---	0
Vanadium	ppm ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 0	<b>0</b>	0	0
Barium	ppm ASTM D5185m 90	<b>2</b>	0	0
Molybdenum	ppm ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm ASTM D5185m	<b>0</b>	0	<1
Magnesium	ppm ASTM D5185m 100	<b>3</b>	<1	61
Calcium	ppm ASTM D5185m 0	<b>0</b>	<1	0
Phosphorus	ppm ASTM D5185m 0	<b>332</b>	2	3
Zinc	ppm ASTM D5185m 0	<b>85</b>	0	15
Sulfur	ppm ASTM D5185m 23500	<b>6403</b>	15626	17327

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >25	<b>&lt;1</b>	2	0
Sodium	ppm ASTM D5185m	<b>2</b>	0	11
Potassium	ppm ASTM D5185m >20	<b>1</b>	0	7
Water	% ASTM D6304 >0.05	<b>▲ 0.114</b>	▲ 0.127	0.017
ppm Water	ppm ASTM D6304 >500	<b>▲ 1140</b>	▲ 1270	173.3




## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>---</b>	258076	21983
Particles >6µm	ASTM D7647 >1300	<b>---</b>	▲ 154980	▲ 8128
Particles >14µm	ASTM D7647 >80	<b>---</b>	▲ 15651	▲ 255
Particles >21µm	ASTM D7647 >20	<b>---</b>	▲ 2067	▲ 34
Particles >38µm	ASTM D7647 >4	<b>---</b>	▲ 51	2
Particles >71µm	ASTM D7647 >3	<b>---</b>	1	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	<b>---</b>	▲ 25/24/21	▲ 20/15

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 1.0	<b>0.20</b>	0.30	0.311


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	<b>NONE</b>	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>▲ MODER</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>● HAZY</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	<b>▲ 0.2%</b>	0.2%	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	45	<b>45.5</b>	46.1	44.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA014668 **Received** : 06 Jun 2024  
**Lab Number** : 06201526 **Tested** : 10 Jun 2024  
**Unique Number** : 11063649 **Diagnosed** : 10 Jun 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**BELLE TIRE**  
 2450 MERCHANTS MILE  
 COLUMBUS, IN  
 US 47201  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: