

COOLANT REPORT

Sample Rating Trend

NORMAL

Area

Morgans Point PROP COMP TANK PROP COMP TANK

Coolant

{not provided} (--- GAL)





DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.


				May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0036516		
Sample Date		Client Info		30 May 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Filtered		
Sample Status				NORMAL		
PHYSICAL TEST F	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.037		
рН	Scale 0-14	ASTM D1287		8.26		
Nitrites	ppm	AP-053:2009		336		
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		27.9		
Freezing Point	°F	ASTM D3321		8		
Total Dissolved Solids				214.0		
Carboxylate				fail		
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130		6		
Phosphorus	ppm	ASTM D6130		788		
Boron	ppm	ASTM D6130		17		
Molybdenum	ppm	ASTM D6130		719		
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	2		
Aluminum	ppm	ASTM D6130	>10	<1		
Copper	ppm	ASTM D6130	>10	7		
Lead	ppm	ASTM D6130	>10	<1		
Tin	ppm	ASTM D6130	>10	<1		
Zinc	ppm	ASTM D6130		5		
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		57		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		828		
Potassium	ppm	ASTM D6130		2589		
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		2		
				-		



COOLANT REPORT









Certificate 12367

Sample No.

: RP0036516 Lab Number : 06201946

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received : 06 Jun 2024 **Tested** : 11 Jun 2024

: 11 Jun 2024 - Jonathan Hester

ENTERPRISE PRODUCTS - MORGAN'S POINT 1200 N BROADWAY LA PORTE, TX US 77571

Unique Number : 11069407 Diagnosed Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType, ICP) To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: JUAN HERRERA jcherrera@eprod.com T: (832)501-4085

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)