


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Machine Id

KAESER CSD 75 6534794 (S/N 1512)

KAESER SIGMA (OEM) M-460 (--- GAL)

Component Compressor

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug2019 .	Jul2020 Mar2021 Oct207	21 Marž022 NovŽ022 JulŽ023	Mar2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA015057	KCPA005704	KCP47030
Sample Date		Client Info		21 Mar 2024	26 Jul 2023	09 Nov 2022
Machine Age	hrs	Client Info		34104	32300	26222
Oil Age	hrs	Client Info		3827	0	4000
Oil Changed		Client Info		Changed	N/A	Not Changd
Sample Status				NORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	8	6	13
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	100	<1	0	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	1	0	<1
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	23500	19179	17972	20371
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		1	1	<1
Potassium	ppm	ASTM D5185m	>20	0	1	0
Water	%	ASTM D6304	>0.05	0.008	0.008	0.016
ppm Water	ppm	ASTM D6304		81	80.9	169.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		152	1615	
Particles >6µm		ASTM D7647	>1300	82	583	
Particles >14µm		ASTM D7647	>80	16	101	
Particles >21µm		ASTM D7647	>20	4	33	
Particles >38µm		ASTM D7647	>4	0	2	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	14/14/11	18/16/14	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.55	0.59	0.55



OIL ANALYSIS REPORT







Certificate 12367

Laboratory

Sample No. Lab Number Unique Number : 11069514

: KCPA015057 : 06202053

Received **Tested**

: 06 Jun 2024 : 07 Jun 2024 Diagnosed

: 09 Jun 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

2050 MARKET ST NE DECATUR, AL US 35601

Contact: STEVEN PERRY STEVEN.PERRY@ARDENMILLS.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: CONDEC [WUSCAR] 06202053 (Generated: 06/09/2024 18:15:23) Rev: 1

Contact/Location: STEVEN PERRY - CONDEC

T:

F: