




# OIL ANALYSIS REPORT

Sample Rating Trend



SEDIMENT



Area

**IRIG [7030866]**

Machine Id

**IRIG-PRM-PMUD-0301 IRIG-PRM-PMUD-0301 #1 MUD PUMP**

Component

**Pump**

Fluid

**MOBIL SHC 634 (140 GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of visible silt present in the sample.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>HLC0003386</b>	HLC0003073	HLC0002819
Sample Date	Client Info		<b>15 May 2024</b>	15 Apr 2024	25 Mar 2024
Machine Age	hrs	Client Info	<b>20926</b>	20571	20390
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	Filtered
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>.1	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >90	<b>36</b>	42	49
Chromium	ppm	ASTM D5185m >5	<b>1</b>	2	<1
Nickel	ppm	ASTM D5185m >5	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m >3	<b>1</b>	2	<1
Silver	ppm	ASTM D5185m >3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >7	<b>19</b>	30	26
Lead	ppm	ASTM D5185m >12	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >30	<b>3</b>	5	2
Tin	ppm	ASTM D5185m >9	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>8</b>	18	6
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	1	0
Magnesium	ppm	ASTM D5185m	<b>3</b>	7	3
Calcium	ppm	ASTM D5185m	<b>12</b>	21	14
Phosphorus	ppm	ASTM D5185m	<b>442</b>	412	450
Zinc	ppm	ASTM D5185m	<b>4</b>	0	0
Sulfur	ppm	ASTM D5185m	<b>62</b>	62	0

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >60	<b>52</b>	79	72
Sodium	ppm	ASTM D5185m	<b>20</b>	35	29
Potassium	ppm	ASTM D5185m >20	<b>15</b>	32	20



## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>320000	---	239187	177689
Particles >6µm	ASTM D7647	>40000	---	98052	83156
Particles >14µm	ASTM D7647	>640	---	1155	424
Particles >21µm	ASTM D7647	>160	---	226	28
Particles >38µm	ASTM D7647	>40	---	3	5
Particles >71µm	ASTM D7647	>10	---	0	4
Oil Cleanliness	ISO 4406 (c)	>25/22/16	---	25/24/17	25/24/16

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.33</b>	0.26	0.38


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	436.4	485	486

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : HLC0003386      **Received** : 06 Jun 2024  
**Lab Number** : 06202079      **Tested** : 11 Jun 2024  
**Unique Number** : 11069540      **Diagnosed** : 11 Jun 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**HILCORP EXPLORATION ALASKA - MILNE POINT**  
 1000 MILNE POINT RD  
 PRUDOE BAY, AK  
 US 99734  
 Contact: Evan Reilly  
 evan.reilly@hilcorp.com  
 T: (907)670-3231  
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)