


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

## 8176150 (S/N 1032) Component Compressor

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

#### DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.


#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KC126155	KC06051494	KC05979643
Sample Date		Client Info		05 Jun 2024	28 Dec 2023	15 Oct 2023
Machine Age	hrs	Client Info		23197	19395	17515
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron		ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m		0 <1	<1	0
	ppm					
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m		2	1	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m		5	8	13
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	1	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	2	<1	0
Calcium	ppm	ASTM D5185m	2	0	<1	0
Phosphorus	ppm	ASTM D5185m		2	17	0
Zinc	ppm	ASTM D5185m		1	0	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	20	<b>4</b> 4	<b>A</b> 37
Sodium	ppm	ASTM D5185m		<1	0	<1
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.05	0.004	0.004	0.008
ppm Water	ppm	ASTM D6304	>500	43	47	83.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8573	650	3382
Particles >6µm		ASTM D7647	>1300	<mark> </mark> 2006	112	919
Particles >14µm		ASTM D7647	>80	70	3	75
Particles >21µm		ASTM D7647	>20	13	0	20
Particles >38µm		ASTM D7647	>4	1	0	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>17/13	<b>e</b> 18/13	14/9	17/13
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.47	0.44	0.38




# **OIL ANALYSIS REPORT**










MOLIAI			11 11 11			
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.5	44.4	44.1
SAMPLE IMAGES	3	method	limit/base	current	history1	history2

Color



Bottom



: 10 Jun 2024

: 10 Jun 2024 - Don Baldridge

Tested

Diagnosed

**5 ARNOLT DRIVE** PIERCETON, IN US 46562 Contact: CHRIS SHOUE christopher.shoue@aludyne.com T: (574)594-9681 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) E:



Report Id: ALUPIE [WUSCAR] 06202704 (Generated: 06/10/2024 13:08:03) Rev: 1

Certificate 12367

Lab Number : 06202704

Unique Number : 11070165

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2

Contact/Location: CHRIS SHOUE - ALUPIE