

OIL ANALYSIS REPORT

Sample Rating Trend **VIS DEBRIS** SAMPLE INFORMATION method

current

historv1

history2

Machine Id KAESER BSD 50T 5950176 (S/N 1363)

Component Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

The oil change at the time of sampling has been noted. We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC128597	KC101641	KC77314
Sample Date		Client Info		24 Apr 2024	05 Jun 2023	20 Jun 2022
Machine Age	hrs	Client Info		23183	20235	17036
Oil Age	hrs	Client Info		3000	3000	3000
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	5	6	5
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ppin				-	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	2
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	29	27	29
Calcium	ppm	ASTM D5185m	2	0	<1	0
Phosphorus	ppm	ASTM D5185m		2	4	6
Zinc	ppm	ASTM D5185m		17	18	12
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	7	7	5
Sodium	ppm	ASTM D5185m		13	6	11
Potassium	ppm	ASTM D5185m	>20	3	<1	3
Water	%	ASTM D6304	>0.05	0.015	0.007	0.032
ppm Water	ppm	ASTM D6304	>500	151	79.4	322.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			4242	3265
Particles >6µm		ASTM D7647	>1300		1415	483
Particles >14µm		ASTM D7647	>80		1 21	55
Particles >21µm		ASTM D7647	>20		0 30	18
Particles >38µm		ASTM D7647	>4		2	1
Particles >71µm		ASTM D7647	>3		0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13		9/18/14	19/16/13
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.37	0.42	0.37
(· •)	3 9					

limit/base

Contact/Location: Service Manager - NAMNEW Page 1 of 2



35


0ct4/18


Sep12/19 -

ug20/20

10/001


OIL ANALYSIS REPORT






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	A MODER	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.4	41.5	44.3
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						


00101



Bottom

lun5/23





Report Id: NAMNEW [WUSCAR] 06202714 (Generated: 06/10/2024 13:14:06) Rev: 1

Contact/Location: Service Manager - NAMNEW