

OIL ANALYSIS REPORT

Area PG-46 [291547] Machine Id PNEUTECH AK100017320 - NORTHFIELD IND Component

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




NORMAL

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0002150		
Sample Date		Client Info		01 Jun 2024		
Machine Age	hrs	Client Info		11972		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		<1		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		273		
Zinc	ppm	ASTM D5185m		26		
Sulfur	ppm	ASTM D5185m		792		
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.24		



OIL ANALYSIS REPORT

VISUAL



	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
1	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
/24	Appearance	scalar	*Visual	NORML	NORML		
Jun1/24	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water			20.1	NEG		
		scalar	*Visual		NEG		
	FLUID PROPER	TIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445		50.0		
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2
- + P2/1 mJ	Color					no image	no image
	Bottom					no image	no image
	Non-ferrous Meta	ıls		Jun1/24			
	Viscosity @ 40°C			Jun1/24	Acid Number		
	50 - Abnormal 50 - 45			.0 .0 .0 (M .0 .0 .0 .0 .0 .0 .0 .0 .0 .0 .0 .0 .0	00		
	Jun1/24)1 Madiso	Madison Ave., Cary, NC 27513 Received : 07 Jun 2024 Tested : 10 Jun 2024 Diagnosed : 10 Jun 2024 - Wes Davis <i>e at 1-800-237-1369.</i>			FLUID-AIRE DYNAMIC 225 SPRING LAKE D ITASCA, US 6014 Contact: ED DIENE ed.diener@fluidairedynamics.cc	

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: UCFLUSCH [WUSCAR] 06202877 (Generated: 06/10/2024 10:51:24) Rev: 1

ŝ,

Contact/Location: ED DIENER - UCFLUSCH

F: