

# **OIL ANALYSIS REPORT**

Sample Rating Trend

### NORMAL

## Area SMO-30 [284654] LS/7/97-03018 - ASHLEY MILLWORK

Component Compressor

### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001204		
Sample Date		Client Info		22 May 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
	N					, , , , , , , , , , , , , , , , , , ,
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		13		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		33		
Zinc	ppm	ASTM D5185m		2		
Sulfur	ppm	ASTM D5185m		4		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.14		



# **OIL ANALYSIS REPORT**

VISUAL



	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
1	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
1	Sand/Dirt	scalar	*Visual	NONE	NONE		
May22/24	Appearance	scalar	*Visual	NORML	NORML		
May	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPER	TIFS	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	innibuse	46.1		motory
	-				40.1		
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Ma/22/24	Color					no image	no image
	Bottom					no image	no image
	Non-ferrous Meta Non-ferrous Meta In In I			May222/24 May222/24 May222/24	Acid Number		
	(3-04) 45 40 35 40 45 40 45 40 45 40 40 40 40 40 40 40 40 40 40			May22224	Ma/2224		
Laboratory Sample No. Lab Number Unique Number Test Package scuss this sample report, motes test methods that	: 11070356 : IND 2 , contact Customer Serv	Rece Teste Diagi vice at 1-8 17025 sco	ived : 07 ed : 10 nosed : 10 800-237-1368 ope of accred	7 Jun 2024 ) Jun 2024 ) Jun 2024 - W 9. ditation.	ed	FLUID-AIRE DYNAMIC 225 SPRING LAKE D ITASCA, I US 6014 Contact: ED DIENE ed.diener@fluidairedynamics.cor T: (847)678-838 1 106:2012) F	

Contact/Location: ED DIENER - UCFLUSCH