

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area SFG-200 [283931] PNEUTECH 1706020004 - ACCORD CARTON

Component Compressor

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of visible silt present in the sample.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORM | IATION | method | limit/base | current | history1 | history2 |
|---------------------------------------|----------|-------------|------------|-------------|-------------|----------|
| Sample Number | | Client Info | | UFD0001479 | UFD0000970 | |
| Sample Date | | Client Info | | 29 May 2024 | 28 Feb 2024 | |
| Machine Age | hrs | Client Info | | 59666 | 0 | |
| Oil Age | hrs | Client Info | | 0 | 0 | |
| Oil Changed | 1110 | Client Info | | Not Changd | N/A | |
| Sample Status | | | | NORMAL | NORMAL | |
| · · · · · · · · · · · · · · · · · · · | | | 11 1. 0 | - | - | |
| CONTAMINATION | N | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >0.1 | NEG | NEG | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 0 | 0 | |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | |
| Nickel | ppm | ASTM D5185m | | 0 | 0 | |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | |
| Silver | ppm | ASTM D5185m | | 0 | 0 | |
| Aluminum | ppm | ASTM D5185m | >25 | 0 | 0 | |
| Lead | ppm | ASTM D5185m | >25 | 0 | 0 | |
| Copper | ppm | ASTM D5185m | >50 | 0 | <1 | |
| Tin | ppm | ASTM D5185m | >15 | 0 | 0 | |
| Vanadium | ppm | ASTM D5185m | | <1 | 0 | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | |
| Barium | ppm | ASTM D5185m | | 0 | 0 | |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | |
| Manganese | ppm | ASTM D5185m | | 0 | <1 | |
| Magnesium | ppm | ASTM D5185m | | <1 | 0 | |
| Calcium | ppm | ASTM D5185m | | 0 | 0 | |
| Phosphorus | ppm | ASTM D5185m | | 314 | 445 | |
| Zinc | ppm | ASTM D5185m | | 5 | 0 | |
| Sulfur | ppm | ASTM D5185m | | 641 | 170 | |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 1 | 0 | |
| Sodium | ppm | ASTM D5185m | | <1 | 2 | |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 0 | |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | 0.30 | 0.42 | |



OIL ANALYSIS REPORT



| | VISUAL | | method | limit/base | current | history1 | history2 | |
|---|---|-------------------------|--|--|-----------|---|----------|--|
| | White Metal | scalar | *Visual | NONE | NONE | NONE | | |
| | Yellow Metal | scalar | *Visual | NONE | NONE | NONE | | |
| | Precipitate | scalar | *Visual | NONE | NONE | NONE | | |
| | Silt | scalar | *Visual | NONE | MODER | NONE | | |
| | Debris | scalar | *Visual | NONE | NONE | NONE | | |
| | Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | | |
| May29/24 | Appearance | scalar | *Visual | NORML | NORML | NORML | | |
| May2 | Odor | scalar | *Visual | NORML | NORML | NORML | | |
| | Emulsified Water | scalar | *Visual | >0.1 | NEG | NEG | | |
| | Free Water | scalar | *Visual | | NEG | NEG | | |
| | FLUID PROPERT | IES | method | limit/base | current | history1 | history2 | |
| | Visc @ 40°C | cSt | ASTM D445 | | 43.5 | 48.9 | | |
| | SAMPLE IMAGES | 6 | method | limit/base | current | history1 | history2 | |
| Ma/29/24 + | Color | | | | | | no image | |
| | Bottom | | | | | | no image | |
| | Non-ferrous Metal | 5 | | 42/62/veW | | | | |
| | Viscosity @ 40°C | | | Acid Number (Ing KOH(g) 2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 | 20 | er | | |
| | Feb 28/24 | | | May29/24 + | Feb 28/24 | | | |
| Laboratory Sample No. Lab Number Unique Number Test Package iscuss this sample report, enotes test methods that | : UFD0001479 : 06202914 : 11070375 : IND 2 contact Customer Servi are outside of the ISO 1 | Recei Teste Diagr | Madison Ave., Cary, NC 27513 Received : 07 Jun 2024 Tested : 10 Jun 2024 Diagnosed : 10 Jun 2024 - Don Baldridge ere at 1-800-237-1369. 1025 scope of accreditation. In the simple acceptance decision rule (JCGI | | | FLUID-AIRE DYNAMIC 225 SPRING LAKE DI ITASCA, I US 6014 Contact: ED DIENEI ed.diener@fluidairedynamics.cor T: (847)678-838 M 106:2012) F | | |

Contact/Location: ED DIENER - UCFLUSCH