

OIL ANALYSIS REPORT

Area S-460 [CSA1097] KAESER YVP03 - BAE SYSTEMS (S/N 1035-8253926)

Component Compressor

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend



| SAMPLE INFORM | NATION | method | limit/base | current | history1 | history2 |
|------------------|---------------|-------------|------------|-------------|-------------|----------|
| Sample Number | | Client Info | | UCH06202929 | UCH06065742 | |
| Sample Date | | Client Info | | 29 May 2024 | 04 Jan 2024 | |
| Machine Age | hrs | Client Info | | 12109 | 8627 | |
| Oil Age | hrs | Client Info | | 0 | 5348 | |
| Oil Changed | | Client Info | | Not Changd | Not Changd | |
| Sample Status | | | | NORMAL | NORMAL | |
| CONTAMINATIO | N | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >0.05 | NEG | NEG | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 2 | 1 | |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | |
| Aluminum | ppm | ASTM D5185m | >10 | <1 | 0 | |
| Lead | ppm | ASTM D5185m | >10 | 0 | 0 | |
| Copper | ppm | ASTM D5185m | >50 | 4 | 2 | |
| Tin | ppm | ASTM D5185m | >10 | 0 | 0 | |
| Vanadium | ppm | ASTM D5185m | | <1 | <1 | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | |
| Barium | ppm | ASTM D5185m | 90 | 106 | 101 | |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | |
| Manganese | ppm | ASTM D5185m | | <1 | 0 | |
| Magnesium | ppm | ASTM D5185m | 90 | 95 | 93 | |
| Calcium | ppm | ASTM D5185m | 2 | 3 | 2 | |
| Phosphorus | ppm | ASTM D5185m | | 6 | <1 | |
| Zinc | ppm | ASTM D5185m | | 9 | 0 | |
| Sulfur | ppm | ASTM D5185m | | 17743 | 17539 | |
| CONTAMINANTS | ; | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 2 | <1 | |
| Sodium | ppm | ASTM D5185m | | 17 | 14 | |
| Potassium | ppm | ASTM D5185m | >20 | 1 | <1 | |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | 0.44 | 0.30 | |




(0-046 44 B

42

Abnormal 40 38 Jan4/24

OIL ANALYSIS REPORT

VISUAL



| Ma/29/24 | White Metal Yellow Metal Precipitate Silt Debris Sand/Dirt Appearance Odor Emulsified Water Free Water | scalar *Vis scalar *Vis | sual NONE sual NONE sual NONE sual NONE sual NONE sual NONE sual NORM sual NORM sual >0.05 sual | NORML NEG NEG | NONE NONE NONE NONE NONE NORML NORML NEG NEG | |
|---|---|---|--|---------------------------|--|---|
| | FLUID PROPER | | ethod limit/b TM D445 46 | ase current 46.3 | history1 45.5 | history2 |
| | SAMPLE IMAGE | :S m | ethod limit/b | ase current | history1 | history2 |
| May29/24 | Color | | | a | a. | no image |
| | Bottom | | | | | no image |
| | Non-ferrous Meta Non-ferrous Meta Non-ferrous Meta Viscosity @ 40°C | | May29/24 | Acid Number | | |
| Laboratory Sample No. Lab Number Unique Number Test Package To discuss this sample report, | : 11070390 : IND 2 | Received Tested Diagnose | : 07 Jun 202 : 10 Jun 202 d : 10 Jun 2024 | 24 24 4 - Wes Davis | INDIA | 05 E 30TH ST NAPOLIS, IN US 46219 LEN PARKER |
| * - Denotes test methods that Statements of conformity to sp CAR] 06202929 (Generated: 06/10/202 | are outside of the ISO a pecifications are based | 17025 scope o | f accreditation. | - | T: (7 5:2012) | 765)516-4920 F: |

Contact/Location: GLEN PARKER - UCAIRIND