

## **FUEL REPORT**



### Machine Id

# **244048**

Component Diesel Fuel Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

#### DIAGNOSIS

#### A Recommendation

We advise that you check for the source of gas entry. Recommend drain fuel if not already done and flush with cleaner before refilling with fuel. Please note that the fuel was too contaminated to perform some of the normal laboratory tests.

#### Contaminants

There is a high concentration of gasoline present in the fuel. There is a light concentration of water present in the fuel.

#### **Fuel Condition**


The fuel is no longer serviceable due to the presence of contaminants.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RY0123420		
Sample Date		Client Info		21 May 2024		
Machine Age	mls	Client Info		0		
Sample Status				SEVERE		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		L4.5		
CONTAMINANTS		method	limit/base	current	history1	history2
Water	%	ASTM D6304	< 0.05	<b>6</b> 0.379		
ppm Water	ppm	ASTM D6304	<500	<u> </u>		
% Gasoline	%	*In-House	<0.50	<b>4</b> 31.2		
% Biodiesel	%	*In-House	<20.0	1.7		
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image


# WEAR

# **FUEL REPORT**

GRAPHS



# Pensky-Martens Flash Point (°C)



Contact/Location: RICHARD BELL - RYDER500