










# FUEL REPORT



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>1373</b>	---	---
Particles >6µm	ASTM D7647	>1300	<b>520</b>	---	---
Particles >14µm	ASTM D7647	>160	<b>43</b>	---	---
Particles >21µm	ASTM D7647	>40	<b>6</b>	---	---
Particles >38µm	ASTM D7647	>10	<b>0</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>18/16/13</b>	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	<b>&lt;1</b>	---	---
Nickel	ppm	ASTM D5185m <0.1	<b>&lt;1</b>	---	---
Lead	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Iron	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Calcium	ppm	ASTM D5185m <0.1	<b>2</b>	---	---
Magnesium	ppm	ASTM D5185m <0.1	<b>&lt;1</b>	---	---
Phosphorus	ppm	ASTM D5185m <0.1	<b>0</b>	---	---
Zinc	ppm	ASTM D5185m <0.1	<b>0</b>	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



no image




no image



no image

no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : JCBDF03938 **Received** : 07 Jun 2024  
**Lab Number** : **06203208** **Tested** : 13 Jun 2024  
**Unique Number** : 11070669 **Diagnosed** : 13 Jun 2024 - Angela Borella  
**Test Package** : DF-2 ( Additional Tests: Fuel, Screen )

**BRIGGS JCB - TAMPA**  
 DBA BRIGGS JCB, 8215 PALM RIVER RD  
 TAMPA, FL  
 US 33619

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: CHRIS RYALS  
 chris.ryals@briggsequipment.com

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)