

# FUEL REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**JOHN DEERE 85G 1FF085GXLMJ022332**  
 Component  
**Diesel Fuel**  
 Fluid  
**No.2 DIESEL FUEL (ULTRALOW SULPHUR) (50 GAL)**

**DIAGNOSIS**

**Recommendation**  
 No corrective action is recommended at this time.

**Corrosion**  
 All metal levels are normal indicating no corrosion in the system.

**Contaminants**  
 The water content is negligible. There is no indication of any contamination in the fuel.

**Fuel Condition**  
 The condition of the fuel is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>JR0222483</b>	---	---
Sample Date	Client Info			<b>07 Jun 2024</b>	---	---
Machine Age	hrs	Client Info		<b>2318</b>	---	---
Sample Status				<b>NORMAL</b>	---	---



PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	3.0	<b>2.3</b>	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	<b>0</b>	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>&lt;1</b>	---	---
Sodium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Potassium	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	---	---
Water	%	ASTM D6304	<0.05	<b>0.007</b>	---	---
ppm Water	ppm	ASTM D6304	<500	<b>79</b>	---	---





HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Nickel	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Lead	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	---	---
Iron	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Calcium	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	---	---
Magnesium	ppm	ASTM D5185m	<0.1	<b>1</b>	---	---
Phosphorus	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	---	---
Zinc	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---

**SAMPLE IMAGES**

	method	limit/base	current	history1	history2	
Color					no image	no image
Bottom					no image	no image

# FUEL REPORT

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : JR0222483      **Received** : 07 Jun 2024  
**Lab Number** : 06203269      **Tested** : 07 Jun 2024  
**Unique Number** : 11070730      **Diagnosed** : 07 Jun 2024 - Doug Bogart  
**Test Package** : CONST ( Additional Tests: KF, PQ, SCREEN )  
*To discuss this sample report, contact Customer Service at 1-800-237-1369.*  
*\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*  
*Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)*

**JRE - GARNER**  
 4161 AUBURN CHURCH RD  
 GARNER, NC  
 US 27529  
 Contact: RALEIGH SHOP  
 sean.betts@jamesriverequipment.com; catherine.anastasio@wearcheck.com  
 T: (919)614-2260  
 F: (919)779-5432