


# **OIL ANALYSIS REPORT**

Sample Rating Trend



MCI/OS/GJ-7302A

**ROYAL PURPLE SYNFILM GT 100 (--- GAL)** 

# Component Blower Fluid

## DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

## Wear

All component wear rates are normal.

## Contamination

Elemental level of silicon (Si) above normal indicating ingress of seal material. The amount and size of particulates present in the system are acceptable.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

Oct2017 Aug2018 Aug2019 Aug2020 Aug2021 Aug2022 Aug2023 Mm202						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0932109	WC0695234	WC0695232
Sample Date		Client Info		23 May 2024	16 Aug 2023	16 Aug 2023
Machine Age	mths	Client Info		0	58	78
Oil Age	mths	Client Info		87	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1	<b>48</b>	1
Chromium	ppm	ASTM D5185m	>20	<1	<1	0
Nickel	ppm	ASTM D5185m	>20	0	<1	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	2	<1	0
Lead	ppm	ASTM D5185m	>20	18	4	15
Copper	ppm	ASTM D5185m	>20	18	2	18
Tin	ppm	ASTM D5185m	>20	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		<1	21	2
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	19	57	15
Calcium	ppm	ASTM D5185m		0	90	<1
Phosphorus	ppm	ASTM D5185m	35	11	25	9
Zinc	ppm	ASTM D5185m		2	8	3
Sulfur	ppm	ASTM D5185m	18000	18111	19974	19427
CONTAMINANTS	<b>3</b>	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<u> </u>	9	13
Sodium	ppm	ASTM D5185m		0	2	0
Potassium	ppm	ASTM D5185m	>20	1	<1	<1
Water	%	ASTM D6304		NEG	NEG	NEG
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	384	<u>▲</u> 17278	1369
Particles >6µm		ASTM D7647	>640	96	<u>^</u> 2406	272
Particles >14µm		ASTM D7647	>80	5	66	22
Particles >21µm		ASTM D7647	>20	1	13	4
Particles >38µm		ASTM D7647	>4	0	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	16/14/10	<u>\$\text{\Delta}\$ 21/18/13</u>	18/15/12
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.388	0.49	0.47	0.53



## OIL ANALYSIS REPORT





Laboratory Sample No. Lab Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: WC0932109 Received : 07 Jun 2024 **Tested** : 11 Jun 2024 : 06203356 Unique Number : 11070817 Diagnosed : 11 Jun 2024 - Angela Borella

Test Package : PLANT ( Additional Tests: KV100, VI ) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: x:

Contact: KENTO OKUHARA

Mitsuo\_Miyahara@jpower.co.jp

JΡ