




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
KAESER DSD 250 4719702 (S/N 1046)
 Component
Compressor
 Fluid
CLEAN AND CLEAR (--- GAL)

DIAGNOSIS

- Recommendation**
 Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.
- Wear**
 Iron ppm levels are abnormal. Aluminum ppm levels are noted.
- Contamination**
 The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.
- Fluid Condition**
 The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KCP45080	KCP45078	KCP33411
Sample Date	Client Info		10 May 2024	17 May 2022	03 May 2021
Machine Age	hrs	Client Info	64954	52294	44357
Oil Age	hrs	Client Info	312	8125	8079
Oil Changed	Client Info		Changed	Changed	Changed
Sample Status			ABNORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	▲ 78	0	0
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	0	0	<1
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >10	● 6	0	0
Lead	ppm	ASTM D5185m >10	0	0	0
Copper	ppm	ASTM D5185m >50	13	10	4
Tin	ppm	ASTM D5185m >10	<1	0	0
Antimony	ppm	ASTM D5185m	---	---	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1
Barium	ppm	ASTM D5185m	0	1	0
Molybdenum	ppm	ASTM D5185m	<1	0	0
Manganese	ppm	ASTM D5185m	0	0	0
Magnesium	ppm	ASTM D5185m	3	<1	<1
Calcium	ppm	ASTM D5185m	0	0	0
Phosphorus	ppm	ASTM D5185m	369	8	1
Zinc	ppm	ASTM D5185m	171	0	0
Sulfur	ppm	ASTM D5185m	2482	12736	14214

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	<1	0
Sodium	ppm	ASTM D5185m	<1	0	<1
Potassium	ppm	ASTM D5185m >20	3	<1	<1
Water	%	ASTM D6304 >0.05	0.033	0.007	0.007
ppm Water	ppm	ASTM D6304 >500	335	75.3	74.0






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		5100	845	637
Particles >6µm	ASTM D7647	>1300	503	211	120
Particles >14µm	ASTM D7647	>80	24	18	15
Particles >21µm	ASTM D7647	>20	4	4	6
Particles >38µm	ASTM D7647	>4	0	0	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	20/16/12	17/15/11	14/11

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.32	0.49	0.392


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.9	45.2	46.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCP45080 **Received** : 07 Jun 2024
Lab Number : 06203403 **Tested** : 11 Jun 2024
Unique Number : 11070864 **Diagnosed** : 11 Jun 2024 - Angela Borella
Test Package : IND 2 (Additional Tests: KF, PrtCount)

JEFFERSON INDUSTRIES
 6670 ST ROUTE 29
 WEST JEFFERSON, OH
 US 43162
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: