




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id

KAESER 7430983

Component

Compressor

Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KCPA018001	KCPA006470	KCP47900D
Sample Date	Client Info		30 May 2024	08 Nov 2023	07 Nov 2022
Machine Age	hrs	Client Info	11119	9308	5960
Oil Age	hrs	Client Info	2000	0	1000
Oil Changed	Client Info		Changed	N/A	Changed
Sample Status			ABNORMAL	NORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	2	0	0
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	0	0	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >10	2	<1	<1
Lead	ppm	ASTM D5185m >10	0	0	0
Copper	ppm	ASTM D5185m >50	2	<1	<1
Tin	ppm	ASTM D5185m >10	<1	<1	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 90	41	16	24
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m	0	0	0
Magnesium	ppm	ASTM D5185m 100	75	75	78
Calcium	ppm	ASTM D5185m 0	0	2	0
Phosphorus	ppm	ASTM D5185m 0	12	1	<1
Zinc	ppm	ASTM D5185m 0	6	0	2
Sulfur	ppm	ASTM D5185m 23500	20949	19210	23257

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	0	0
Sodium	ppm	ASTM D5185m	15	6	6
Potassium	ppm	ASTM D5185m >20	4	1	0
Water	%	ASTM D6304 >0.05	0.020	0.018	▲ 0.174
ppm Water	ppm	ASTM D6304 >500	202	188.5	▲ 1740






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		11084	2718	2134
Particles >6µm	ASTM D7647	>1300	▲ 4320	875	318
Particles >14µm	ASTM D7647	>80	▲ 235	47	14
Particles >21µm	ASTM D7647	>20	● 34	9	2
Particles >38µm	ASTM D7647	>4	1	0	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 21/19/15	19/17/13	18/15/11

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.35	0.32	0.40


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	48.6	48.5	46.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA018001 **Received** : 07 Jun 2024
Lab Number : 06203404 **Tested** : 11 Jun 2024
Unique Number : 11070865 **Diagnosed** : 11 Jun 2024 - Angela Borella
Test Package : IND 2 (Additional Tests: KF, PrtCount)

AMAZON.COM SERVICES LLC
 1255 GATEWAY BLVD
 BELOIT, WI
 US 53511
 Contact: N. OSCHOFF
 noschoff@amazon.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)