

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AIRTOWER 7.5C 5919917 (S/N 1548)

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil. Appearance is hazy There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

				May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017991		
Sample Date		Client Info		31 May 2024		
Machine Age	hrs	Client Info		1253		
Oil Age	hrs	Client Info		1253		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
· ·				-		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	9		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	2		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m	>50	<u>^</u> 64		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
					HISTORY	HIStory2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	100	<1		
Calcium	ppm	ASTM D5185m	0	0		
Phosphorus	ppm	ASTM D5185m	0	8		
Zinc	ppm	ASTM D5185m	0	5		
Sulfur	ppm	ASTM D5185m	23500	19338		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	<1		
Water	%	ASTM D6304	>0.05	△ 0.070		
ppm Water	ppm	ASTM D6304	>500	<u>^</u> 700		
FLUID CLEANLIN	FSS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	1000	1253		
Particles >6µm		ASTM D7647		682		
Particles >14µm		ASTM D7647	>80	116		
Particles >21µm		ASTM D7647		39		
Particles >38µm		ASTM D7647	>4	6		
Particles >71µm		ASTM D7647		1		
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/17/14		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.39		



OIL ANALYSIS REPORT







Certificate 12367

Sample No.

: KCPA017991 Lab Number : 06203413 Unique Number : 11070874

Received : 07 Jun 2024 Tested : 13 Jun 2024 Diagnosed : 13 Jun 2024 - Angela Borella

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. 36000 ALABAMA HWY 21 TALLADEGA, AL US 35160

Contact: NEIL TURNER neil_turner@precision-strip.com T:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: