




FUEL REPORT

Sample Rating Trend



NORMAL



Area

Procacci Development-Miami [17675]

Machine Id

[Procacci Development-Miami] F-2B

Component

Diesel Fuel

Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (350 GAL)

DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the fuel.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0953957	WC06139459	---
Sample Date	Client Info			30 May 2024	28 Mar 2024	---
Machine Age	hrs	Client Info		0	0	---
Sample Status				NORMAL	ABNORMAL	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yellow	Red	Red	---
ASTM Color	scalar	*ASTM D1500		L4.5	L4.5	---
Visc @ 40°C	cSt	ASTM D445	3.0	2.28	2.36	---
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	62.6	65.1	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0	0	---
Sulfur (UVF)	ppm	ASTM D5453		6	8	---






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	173	176	---
5% Distillation Point	°C	ASTM D86		189	195	---
10% Distill Point	°C	ASTM D86	201	197	203	---
15% Distillation Point	°C	ASTM D86		204	210	---
20% Distill Point	°C	ASTM D86	216	210	217	---
30% Distill Point	°C	ASTM D86	230	224	230	---
40% Distill Point	°C	ASTM D86	243	238	243	---
50% Distill Point	°C	ASTM D86	255	251	255	---
60% Distill Point	°C	ASTM D86	267	266	270	---
70% Distill Point	°C	ASTM D86	280	281	284	---
80% Distill Point	°C	ASTM D86	295	299	300	---
85% Distillation Point	°C	ASTM D86		310	311	---
90% Distill Point	°C	ASTM D86	310	322	322	---
95% Distillation Point	°C	ASTM D86		341	339	---
Final Boiling Point	°C	ASTM D86	341	356	355	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	37	38	---
Cetane Index		ASTM D4737	<40.0	48	50	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1	0	---
Sodium	ppm	ASTM D5185m	<0.1	2	<1	---
Potassium	ppm	ASTM D5185m	<0.1	2	0	---
Water	%	ASTM D6304	<0.05	0.003	0.016	---
ppm Water	ppm	ASTM D6304	<500	40	165	---
% Gasoline	%	*In-House	<0.50	0.0	0.0	---
% Biodiesel	%	*In-House	<20.0	0.0	0.0	---



FUEL REPORT



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	162	▲ 10113	---
Particles >6µm	ASTM D7647	>640	44	▲ 2553	---
Particles >14µm	ASTM D7647	>80	5	▲ 139	---
Particles >21µm	ASTM D7647	>20	1	▲ 27	---
Particles >38µm	ASTM D7647	>4	0	0	---
Particles >71µm	ASTM D7647	>3	0	0	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	15/13/10	▲ 21/19/14	---




HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	0	0	---
Nickel	ppm	ASTM D5185m <0.1	0	0	---
Lead	ppm	ASTM D5185m <0.1	1	0	---
Vanadium	ppm	ASTM D5185m <0.1	0	0	---
Iron	ppm	ASTM D5185m <0.1	<1	0	---
Calcium	ppm	ASTM D5185m <0.1	0	0	---
Magnesium	ppm	ASTM D5185m <0.1	0	0	---
Phosphorus	ppm	ASTM D5185m <0.1	0	0	---
Zinc	ppm	ASTM D5185m <0.1	0	0	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

no image

no image

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0953957 **Received** : 07 Jun 2024
Lab Number : **06204067** **Tested** : 14 Jun 2024
Unique Number : 11071528 **Diagnosed** : 14 Jun 2024 - Elizabeth Valachovic
Test Package : DF-2 (Additional Tests: Fuel, Screen)

PETROLEUM RECOVERY SERVICES
 210 POWELL DR
 SUMMERVILLE, SC
 US 29483
 Contact: AJAY EL
 Ajay@prsfuel.com
 T: (843)225-1777
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)