


FUEL REPORT

QTS ATLANTA GA DC1 [4637] [QTS ATLANTA GA DC1] GA6

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR)





DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets ASTM D975 specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no bacteria or fungus (yeast and/or mold) present in the sample. The water content is negligible. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the fuel.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

) (3500 GAL)				May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0953964		
Sample Date		Client Info		22 May 2024		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
uel Color	text	*Visual Screen	Yllow	Red		
STM Color	scalar	*ASTM D1500		L4.5		
/isc @ 40°C	cSt	ASTM D445	3.0	2.5		
ensky-Martens Flash Point	°C	*PMCC Calculated	52	61.3		
SULFUR CONTER	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0		
Sulfur (UVF)	ppm	ASTM D5453		8		
DISTILLATION		method	limit/base	current	history1	history2
nitial Boiling Point	°C	ASTM D86	165	172		
% Distillation Point	°C	ASTM D86		194		
0% Distill Point	°C	ASTM D86	201	204		
5% Distillation Point	°C	ASTM D86		211		
0% Distill Point	°C	ASTM D86	216	219		
0% Distill Point	°C	ASTM D86	230	234		
0% Distill Point	°C	ASTM D86	243	247		
60% Distill Point	°C	ASTM D86	255	261		
60% Distill Point	°C	ASTM D86	267	275		
'0% Distill Point	°C	ASTM D86	280	289		
80% Distill Point	°C	ASTM D86	295	304		
5% Distillation Point	°C	ASTM D86		315		
00% Distill Point	°C	ASTM D86	310	326		
95% Distillation Point	°C	ASTM D86	3.0	345		
Final Boiling Point	°C	ASTM D86	341	359		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36		
Cetane Index		ASTM D4737	<40.0	48		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1		
Sodium	ppm	ASTM D5185m	< 0.1	1		
Potassium	ppm	ASTM D5185m	<0.1	2		
Vater	%	ASTM D6304	< 0.05	0.00		
pm Water	ppm	ASTM D6304	<500	0		
6 Gasoline	%	*In-House	< 0.50	0.0		
2/ Biodiocal	0/	*In House	~20 O	0.0		


*In-House <20.0

0.0

% Biodiesel



FUEL REPORT







Certificate 12367

Sample No.

Lab Number : 06204087 Unique Number: 11071548

: WC0953964

Received **Tested**

: 17 Jun 2024 Diagnosed

: 17 Jun 2024 - Elizabeth Valachovic

Test Package : DF-2 (Additional Tests: Fuel, Screen) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

SUMMERVILLE, SC US 29483

Contact: AJAY EL Ajay@prsfuel.com T: (843)225-1777