


FUEL REPORT

QTS ATLANTA GA DC1 [4634] [QTS ATLANTA GA DC1] GA3

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR





DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets ASTM D975 specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

R) (3500 GAL)				May2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0953958		
Sample Date		Client Info		22 May 2024		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yllow	Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445	3.0	2.54		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	60.3		
SULFUR CONTE	٧T	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0		
Sulfur (UVF)	ppm	ASTM D5453		8		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	171		
5% Distillation Point	°C	ASTM D86		192		
10% Distill Point	°C	ASTM D86	201	202		
15% Distillation Point	°C	ASTM D86		210		
20% Distill Point	°C	ASTM D86	216	218		
30% Distill Point	°C	ASTM D86	230	233		
40% Distill Point	°C	ASTM D86	243	246		
50% Distill Point	°C	ASTM D86	255	260		
60% Distill Point	°C	ASTM D86	267	274		
70% Distill Point	°C	ASTM D86	280	288		
80% Distill Point	°C	ASTM D86	295	304		
85% Distillation Point	°C	ASTM D86		315		
90% Distill Point	°C	ASTM D86	310	326		
95% Distillation Point	°C	ASTM D86		345		
Final Boiling Point	°C	ASTM D86	341	359		
IGNITION QUALIT	Υ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36		
Cetane Index		ASTM D4737	<40.0	48		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1		
Sodium	ppm	ASTM D5185m	<0.1	2		
Potassium	ppm	ASTM D5185m	< 0.1	2		
Water	%	ASTM D6304	< 0.05	0.00		
ppm Water	ppm	ASTM D6304	< 500	0		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



FUEL REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06204088 Unique Number : 11071549

: WC0953958

Received : 07 Jun 2024 **Tested**

Diagnosed Test Package : DF-2 (Additional Tests: Fuel, Screen)

: 17 Jun 2024

: 17 Jun 2024 - Elizabeth Valachovic

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (843)225-1777 Contact/Location: AJAY EL - PETSUM

210 POWELL DR

Contact: AJAY EL

Ajay@prsfuel.com

US 29483

SUMMERVILLE, SC