




PROBLEM SUMMARY


Area
Paper Machine
 Machine Id
Pick-up Roll Suction Gearbox
 Component
Gearbox
 Fluid
MOBIL MOBILGEAR SHC 320 (--- GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

| Sample Status | | | SEVERE | SEVERE | ABNORMAL |
|-----------------|--------------|-----------|------------|------------|------------|
| Particles >4µm | ASTM D7647 | >20000 | ▲ 170957 | ▲ 145868 | ▲ 74428 |
| Particles >6µm | ASTM D7647 | >5000 | ▲ 97137 | ▲ 57129 | 4766 |
| Particles >14µm | ASTM D7647 | >640 | ▲ 3308 | 182 | 37 |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | ▲ 25/24/19 | ▲ 24/23/15 | ▲ 23/19/12 |

Customer Id: CASASH
 Sample No.: WC0776530
 Lab Number: 06204635
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Wes Davis +1 905-569-8600 x223
wesd@wearcheck.ca


To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|----------------------|--------|------|---------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Change Filter | --- | --- | ? | We recommend you service the filters on this component. |
| Resample | --- | --- | ? | Resample in 30-45 days to monitor this situation. |
| Information Required | --- | --- | ? | NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. |
| Check Breathers | --- | --- | ? | The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. |
| Check Seals | --- | --- | ? | Check seals and/or filters for points of contaminant entry. |


HISTORICAL DIAGNOSIS

ISO




26 Jan 2024 Diag: Wes Davis
 Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report




ISO




11 Aug 2023 Diag: Don Baldrige
 No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report




ISO



26 May 2023 Diag: Wes Davis
 We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

Paper Machine

Machine Id

Pick-up Roll Suction Gearbox

Component

Gearbox

Fluid

MOBIL MOBILGEAR SHC 320 (--- GAL)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0776530 | WC0776446 | WC0776605 |
| Sample Date | Client Info | | 06 Jun 2024 | 26 Jan 2024 | 11 Aug 2023 |
| Machine Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | N/A | N/A | N/A |
| Sample Status | | | SEVERE | SEVERE | ABNORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|------------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m >200 | 56 | 59 | 3 |
| Chromium | ppm | ASTM D5185m >15 | <1 | <1 | 0 |
| Nickel | ppm | ASTM D5185m >15 | <1 | <1 | 2 |
| Titanium | ppm | ASTM D5185m | 0 | 0 | <1 |
| Silver | ppm | ASTM D5185m | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m >25 | <1 | <1 | <1 |
| Lead | ppm | ASTM D5185m >100 | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185m >200 | <1 | 2 | 35 |
| Tin | ppm | ASTM D5185m >25 | <1 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | <1 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | <1 | 0 | 0 |
| Barium | ppm | ASTM D5185m | <1 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | 1 | <1 | <1 |
| Magnesium | ppm | ASTM D5185m | 2 | <1 | 2 |
| Calcium | ppm | ASTM D5185m | 7 | 9 | 0 |
| Phosphorus | ppm | ASTM D5185m | 480 | 466 | 486 |
| Zinc | ppm | ASTM D5185m | 9 | <1 | 5 |
| Sulfur | ppm | ASTM D5185m | 2746 | 2393 | 2978 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >50 | 24 | 15 | 21 |
| Sodium | ppm | ASTM D5185m | 4 | 4 | <1 |
| Potassium | ppm | ASTM D5185m >20 | 4 | 4 | 2 |
| Water | % | ASTM D6304 >0.2 | 0.003 | 0.007 | 0.010 |
| ppm Water | ppm | ASTM D6304 >2000 | 40 | 73 | 106.1 |

FLUID CLEANLINESS






| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-------------------|------------|------------|
| Particles >4µm | ASTM D7647 | >20000 | ▲ 170957 | ▲ 145868 | ▲ 74428 |
| Particles >6µm | ASTM D7647 | >5000 | ▲ 97137 | ▲ 57129 | 4766 |
| Particles >14µm | ASTM D7647 | >640 | ▲ 3308 | 182 | 37 |
| Particles >21µm | ASTM D7647 | >160 | ● 302 | 20 | 12 |
| Particles >38µm | ASTM D7647 | >40 | 5 | 0 | 3 |
| Particles >71µm | ASTM D7647 | >10 | 1 | 0 | 1 |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | ▲ 25/24/19 | ▲ 24/23/15 | ▲ 23/19/12 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.94 | 0.80 | 1.24 |




OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.2 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 320 | 318 | 319 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0776530
Lab Number : 06204635
Unique Number : 11072096
Test Package : PLANT
Received : 10 Jun 2024
Tested : 12 Jun 2024
Diagnosed : 12 Jun 2024 - Wes Davis

CASCADES CONTAINERBOARD PACKAGING - BEARPACK PROJECT
 10026 OLD RIDGE ROAD
 ASHLAND, VA
 US 23005
 Contact: MARC-ANDRE HUBERT
 marc-andre_hubert@cascades.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)