


PROBLEM SUMMARY

COFICAB

202202160051


Air Compressor


SULLAIR SULLUBE (15 GAL)







COMPONENT CONDITION SUMMARY









RECOMMENDATION

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS									
Sample Status				SEVERE					
Tin	ppm	ASTM D5185m	>5	<u>^</u> 9					
Particles >4µm		ASTM D7647	>10000	24699					
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>^</u> 22/17/13		***			
Acid Number (AN)	mg KOH/g	ASTM D8045	.06	3.896					
Visc @ 40°C	cSt	ASTM D445	38.1	<u>▲</u> 60.1					

Customer Id: SFA604630 Sample No.: SFA0000202 Lab Number: 06204658 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Fluid			?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.			
Flush System			?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.			
Resample			?	We recommend an early resample to monitor this condition.			

HISTORICAL DIAGNOSIS




OIL ANALYSIS REPORT

COFICAB

202202160051

Air Compressor

SULLAIR SULLUBE (15 GAL)





DIAGNOSIS

Recommendation

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition.

The tin level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 6 microns in size) present in the oil.

▲ Fluid Condition

The AN level is above the recommended limit. The oil viscosity is higher than normal. The oil is no longer serviceable.

				May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
	MATION		IIIIIIVDase		•	HISTOLYZ
Sample Number		Client Info		SFA0000202		
Sample Date		Client Info		30 May 2024		
Machine Age	hrs	Client Info		10205		
Oil Age	hrs	Client Info		2212		
Oil Changed		Client Info		N/A		
Sample Status				SEVERE		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>4	0		
Nickel	ppm	ASTM D5185m	>4	<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>10	1		
Lead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>40	2		
Tin	ppm	ASTM D5185m	>5	<u> </u>		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		2		
Barium	ppm	ASTM D5185m	745	320		
Molybdenum	ppm	ASTM D5185m	0.0	0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	0.0	4		
Calcium	ppm	ASTM D5185m	1	8		
Phosphorus	ppm	ASTM D5185m	3	6		
Zinc	ppm	ASTM D5185m	0.1	11		
Sulfur	ppm	ASTM D5185m	240	599		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	9		
Sodium	ppm	ASTM D5185m		106		
Potassium	ppm	ASTM D5185m	>20	28		
Water	%	ASTM D6304	>0.6	0.444		
ppm Water	ppm	ASTM D6304	>6000	4440		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000	4 24699		
Particles >6µm		ASTM D7647	>2500	1003		
Particles >14µm		ASTM D7647	>320	61		
Particles >21µm		ASTM D7647	>80	16		
Particles >38µm		ASTM D7647	>20	1		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	22/17/13		
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2
Acid Number (AN)	I/OII/-	ACTM DOG45	06	A 2 006		


Acid Number (AN)

mg KOH/g ASTM D8045 .06

3.896



OIL ANALYSIS REPORT





Certificate 12367

Report Id: SFA604630 [WUSCAR] 06204658 (Generated: 06/12/2024 18:22:44) Rev: 1

Sample No.

: SFA0000202 Lab Number : 06204658 Unique Number : 11072119

Received : 10 Jun 2024 **Tested** : 12 Jun 2024 Diagnosed

: 12 Jun 2024 - Doug Bogart

Test Package: PLANT (Additional Tests: FT-IR, KF, pH) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

MARTIN CARRERA 567 PTE MONTERREY, ZZ

MX 64290

Contact: Service Manager tampico@kalte.com.mx

T: F:

Contact/Location: Service Manager - SFA604630