

PROBLEM SUMMARY

Sample Rating Trend

WEAR


2017 May2018 Feb2019 Dez2019 Dez2020 Jul2022 Jul2022 Mar2022 Feb2024


AIR 2 (S/N 1004)


Air Compressor


USPI MAX FG AIR 46 (--- GAL)

COMPONENT CONDITION SUMMARY









RECOMMENDATION

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS									
Sample Status				SEVERE	NORMAL	NORMAL			
Copper	ppm	ASTM D5185m	>40	118	1	2			
Acid Number (AN)	mg KOH/g	ASTM D8045	0.16	15.38	0.23	0.21			
Visc @ 40°C	cSt	ASTM D445	45.8	A 82.3	47.4	47.0			

Customer Id: AMEGREEAS Sample No.: USPM37592 Lab Number: 06204675 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com


To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.		
Flush System			?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.		
Resample			?	We recommend an early resample to monitor this condition.		

HISTORICAL DIAGNOSIS

06 Feb 2024 Diag: Doug Bogart

NORMAL





NORMAL



28 Sep 2023 Diag: Doug Bogart
Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



NORMAL



21 Jun 2023 Diag: Doug Bogart


Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



AIR 2 (S/N 1004)

Air Compressor

USPI MAX FG AIR 46 (--- GAL)

DIAGNOSIS

▲ Recommendation

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition.

A Wear

Bearing and/or bushing wear is indicated.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition

The AN level is above the recommended limit. The oil viscosity is higher than normal. Confirmed.

		ct2017 May20	18 Feb 2019 Dec 2019 O	ct2020 Jul2021 Jun2022 Mar202	3 Feb2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM37592	USPM30063	USPM29790
Sample Date		Client Info		31 May 2024	06 Feb 2024	28 Sep 2023
Machine Age	hrs	Client Info		56879	55107	53751
Oil Age	hrs	Client Info		0	27389	26033
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	0	<1
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>4	<1	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	0
Lead	ppm	ASTM D5185m	>20	2	<1	0
Copper	ppm	ASTM D5185m	>40	118	1	2
Tin	ppm	ASTM D5185m	>5	2	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	1	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	0	3	1	<1
Calcium	ppm	ASTM D5185m	0	3	1	0
Phosphorus	ppm	ASTM D5185m	0	2	1	1
Zinc	ppm	ASTM D5185m	0	835	2	4
Sulfur	ppm	ASTM D5185m	0	31	16	57
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	6	6	5
Sodium	ppm	ASTM D5185m		19	<1	0
Potassium	ppm	ASTM D5185m	>20	6	2	<1
Water	%	ASTM D6304	>0.6	0.103	0.002	0.020
ppm Water	ppm	ASTM D6304	>6000	1035	22	208.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		453	888	118
Particles >6µm		ASTM D7647	>1300	177	284	48
Particles >14μm		ASTM D7647	>80	27	22	9
Particles >21µm		ASTM D7647	>20	10	3	4
Particles >38µm		ASTM D7647	>4	1	0	1
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	16/15/12	17/15/12	14/13/10
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.16	15.38	0.23	0.21



OIL ANALYSIS REPORT



 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: