



PROBLEM SUMMARY





AIR 4 (S/N 1530 - 101265.1)


Air Compressor Fluid USPI MAX FG AIR 46 (--- GAL)

COMPONENT CONDITION SUMMARY









RECOMMENDATION

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE	NORMAL	NORMAL		
Acid Number (AN)	mg KOH/g	ASTM D8045	0.16	3.83	0.20	0.12		
Visc @ 40°C	cSt	ASTM D445	45.8	55.7	47.6	46.5		

Customer Id: AMEGREEAS Sample No.: USPM37591 Lab Number: 06204676 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Fluid			?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.			
Flush System			?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.			
Resample			?	We recommend an early resample to monitor this condition.			

HISTORICAL DIAGNOSIS



06 Feb 2024 Diag: Doug Bogart

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report



28 Sep 2023 Diag: Doug Bogart

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



NORMAL

21 Jun 2023 Diag: Doug Bogart

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

DEGRADATION

X

Machine Id

AIR 4 (S/N 1530 - 101265.1)

Component Air Compressor Fluid

USPI MAX FG AIR 46 (--- GAL)

DIAGNOSIS

Recommendation

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition.

🛑 Wear

Bearing and/or bushing wear is indicated.

Contamination

There is a moderate amount of particulates present in the oil.


Fluid Condition


The AN level is above the recommended limit. The oil viscosity is higher than normal. Confirmed.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM37591	USPM30064	USPM29788
Sample Date		Client Info		31 May 2024	06 Feb 2024	28 Sep 2023
Machine Age	hrs	Client Info		23689	21940	19418
Oil Age	hrs	Client Info		0	12184	9662
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>4	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>20	0	<1	0
Copper	ppm	ASTM D5185m	>40	<u> </u>	1	2
Tin	ppm	ASTM D5185m	>5	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	0	<1	1	0
Calcium	ppm	ASTM D5185m	0	<1	1	0
Phosphorus	ppm	ASTM D5185m	0	2	0	1
Zinc	ppm	ASTM D5185m	0	<u> </u>	2	4
Sulfur	ppm		0	15	16	3
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		5	<1	0
Potassium	ppm	ASTM D5185m	>20	4	2	<1
Water	%	ASTM D6304	>0.6	0.023	0.004	0.022
ppm Water	ppm	ASTM D6304	>6000	240	42	227.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1222	713	1211
Particles >6µm		ASTM D7647	>1300	554	39	195
Particles >14µm		ASTM D7647	>80	e 103	6	23
Particles >21µm		ASTM D7647	>20	931	4	7
Particles >38µm		ASTM D7647	>4	1	1	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	— 17/16/14	17/12/10	17/15/12
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.16	3.83	0.20	0.12




OIL ANALYSIS REPORT










VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45.8	▲ 55.7	47.6	46.5
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color					All -	
Bottom						



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: AMEGREEAS [WUSCAR] 06204676 (Generated: 06/12/2024 19:51:51) Rev: 1

Certificate 12367

Contact/Location: Service Manager - AMEGREEAS

Page 4 of 4

T:

F: