


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

AC-1 (S/N V1689U12320)

Component Air Compressor

Fluid

USPI MAX FG AIR 46 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of visible silt present in the sample. Free water present.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Marž021	Apr2022 Jul2022	Nov2022 Jun2023 Jan2024	Jun2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM37587	USPM30565	USPM28955
Sample Date		Client Info		05 Jun 2024	05 Jan 2024	25 Jun 2023
Machine Age	hrs	Client Info		58162	55179	51404
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>4	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	1	2	2
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>40	0	<1	<1
Tin	ppm	ASTM D5185m	>5	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	0	0	0	0
Calcium	ppm	ASTM D5185m	0	3	2	2
Phosphorus	ppm	ASTM D5185m	0	<1	1	2
Zinc	ppm	ASTM D5185m	0	49	56	36
Sulfur	ppm	ASTM D5185m	0	<1	0	0
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		1	<1	<1
Potassium	ppm	ASTM D5185m		2	<1	<1
Water	%	ASTM D6304	>0.6	0.099	0.021	0.113
ppm Water	ppm	ASTM D6304	>6000	990	218	1130
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000			12222
Particles >6µm		ASTM D7647	>2500			4035
Particles >14μm		ASTM D7647	>640			863
Particles >21μm		ASTM D7647	>160			465
Particles >38μm		ASTM D7647	>40			60
Particles >71μm		ASTM D7647	>10			3
Oil Cleanliness		ISO 4406 (c)	>20/18/16			21/19/17
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.16	0.51	0.46	0.49



OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	0.2%	NEG	0.2%
Free Water	scalar	*Visual		<u> </u>	NEG	▲ 10.0
FLUID PROPERTIES		method	limit/base	current	history1	history2

Visc @ 40°C	cSt	ASTM D445	45.8	50.0	50.7	49.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color
























Laboratory Sample No. Lab Number : 06204679 Unique Number : 11072140

: USPM37587

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested** Diagnosed

: 10 Jun 2024 : 12 Jun 2024 : 12 Jun 2024 - Doug Bogart

FORT MYERS, FL US 33905 Contact: RON MOGENSEN

5521 DIVISION DR

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

ronnie.mogensen@kraftheinz.com T:

KraftHeinz - Fort Myers - Plant 8374

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: KRAFORFL [WUSCAR] 06204679 (Generated: 06/12/2024 19:53:53) Rev: 2

Contact/Location: RON MOGENSEN - KRAFORFL

F: