


# OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id  
**NK 112624**  
 Component  
**Compressor**  
 Fluid  
**CIMARRON HB-150 (--- GAL)**

**DIAGNOSIS**

**Recommendation**  
 We recommend you service the filters on this component. Resample at the next service interval to monitor. Please note that this is a corrected copy.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 There is a high amount of particulates present in the oil.

**Fluid Condition**  
 The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>TO90004136</b>	TO90004189	---
Sample Date	Client Info			<b>09 Jun 2024</b>	05 Apr 2024	---
Machine Age	hrs	Client Info		<b>0</b>	0	---
Oil Age	hrs	Client Info		<b>0</b>	0	---
Oil Changed	Client Info			<b>N/A</b>	N/A	---
Sample Status				<b>ABNORMAL</b>	ABNORMAL	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>5</b>	4	---
Chromium	ppm	ASTM D5185m	>10	<b>&lt;1</b>	<1	---
Nickel	ppm	ASTM D5185m		<b>0</b>	<1	---
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	---
Silver	ppm	ASTM D5185m		<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m	>25	<b>&lt;1</b>	2	---
Lead	ppm	ASTM D5185m	>25	<b>1</b>	0	---
Copper	ppm	ASTM D5185m	>50	<b>&lt;1</b>	<1	---
Tin	ppm	ASTM D5185m	>15	<b>2</b>	<1	---
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	---
Cadmium	ppm	ASTM D5185m		<b>0</b>	<1	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<b>1</b>	<1	---
Barium	ppm	ASTM D5185m	0	<b>0</b>	<1	---
Molybdenum	ppm	ASTM D5185m	0	<b>0</b>	<1	---
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	---
Magnesium	ppm	ASTM D5185m	0	<b>0</b>	<1	---
Calcium	ppm	ASTM D5185m	0	<b>0</b>	3	---
Phosphorus	ppm	ASTM D5185m	0	<b>42</b>	15	---
Zinc	ppm	ASTM D5185m	0	<b>38</b>	2	---
Sulfur	ppm	ASTM D5185m	0	<b>363</b>	116	---


CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>&lt;1</b>	4	---
Sodium	ppm	ASTM D5185m		<b>0</b>	4	---
Potassium	ppm	ASTM D5185m	>20	<b>4</b>	2	---
Water	%	ASTM D6304	>2.26	<b>0.614</b>	0.181	---
ppm Water	ppm	ASTM D6304	>22600	<b>6148</b>	1816	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<b>▲ 32033</b>	---	---
Particles >6µm		ASTM D7647	>2500	<b>▲ 10146</b>	---	---
Particles >14µm		ASTM D7647	>320	<b>▲ 656</b>	---	---
Particles >21µm		ASTM D7647	>80	<b>▲ 95</b>	---	---
Particles >38µm		ASTM D7647	>20	<b>4</b>	---	---
Particles >71µm		ASTM D7647	>4	<b>0</b>	---	---
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<b>▲ 22/21/17</b>	---	---


FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.35</b>	0.11	---

# OIL ANALYSIS REPORT


## Particle Trend




## Water (KF)




## Viscosity @ 100°C



## Water (KF)




## Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ MODER	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>2.26	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	151	147	---
Visc @ 100°C	cSt	ASTM D445	26.2	26.8	---
Viscosity Index (VI)	Scale	ASTM D2270	224	220	---

## SAMPLE IMAGES



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO90004136  
**Lab Number** : 06204744  
**Unique Number** : 11072205  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**CIMARRON ENERGY - CARLSBAD**  
 4425 GRANDI RD, UNIT F  
 CARLSBAD, NM  
 UM 88220-8923  
 Contact: CARLOS LEAL  
 cleal@cimarron.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)