### Sullivan <u>uvan</u> Palatek.

# **OIL ANALYSIS REPORT**

## Area ULTIMA 46 **SULLIVAN PALATEK 11F016 - BRITTEN** Component Compressor

#### Recommendation

Resample at the next service interval to monitor.

#### Wear


All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




Sample Rating Trend


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCS06204795	UCS05280857	
Sample Date		Client Info		29 May 2024	01 Jun 2021	
Machine Age	hrs	Client Info		109235	84435	
Oil Age	hrs	Client Info		0	6993	
Oil Changed		Client Info		Changed	Not Changd	
Sample Status				NORMAL	NORMAL	
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.8	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	2	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	2	0	
Lead	ppm	ASTM D5185m	>25	<1	<1	
Copper	ppm	ASTM D5185m	>50	<1	<1	
Tin	ppm	ASTM D5185m	>15	<1	<1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	0	1	
Barium	ppm	ASTM D5185m	525	95	0	
Molybdenum	ppm	ASTM D5185m	10	0	<1	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	5	0	1	
Calcium	ppm	ASTM D5185m	10	0	23	
Phosphorus	ppm	ASTM D5185m	250	56	52	
Zinc	ppm	ASTM D5185m	100	31	16	
Sulfur	ppm	ASTM D5185m	400	134	98	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	3	
Sodium	ppm	ASTM D5185m		19	52	
Potassium	ppm	ASTM D5185m	>20	2	<1	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.09	0.420	



# **OIL ANALYSIS REPORT**

VISUAI





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.8	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	40.1	50.3	
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color				A.		no image
Bottom					(4)	no image
GRAPHS						
2 0 1 2/1 unr			May29/24			
Non-ferrous Metal	S					
Jun1/21			May29/24			
Viscosity @ 40°C			1.2	Acid Number		
0 -			(B) HOX 0.9 (B) HOX 0.9 (B) HOX 0.7 (B) HOX 0.4 (B) HOX 0.2 (B) HOX 0.2 (B) HOX 0.2 (B) HOX 0.2 (B) HOX 0.2 (B) HOX 0.9 (B) HO	5		
5- Abnormal			E 0.7	2		
Abnormal			Q 0.4	-		
			2 0.2	1		
12/1 unf			A 0.0	Jun 1/21		ACRC. M
VearCheck USA - 50 <sup>-</sup>	1 Madisc		, NC 27513			
ICS06204795 <mark>6204795</mark> 1072256 ND 2 ntact Customer Servi	Recei Teste Diagr	ived : 10 id : 12 nosed : 12	) Jun 2024 2 Jun 2024 Jun 2024 - Se	an Felton		ERSE CITY, M US 4968 Contact: MIKI ce@airlex.cor

To discuss this sample report, contact Customer Se -800-23 1365

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Laboratory

Sample No.

Lab Number

**Unique Number Test Package** 

Contact/Location: MIKE ? - UCAIRTRA

F:

T: (231)929-1601