


OIL ANALYSIS REPORT

PG-46 [289649] PNEUTECH AK100010367 - HIRE-NELSON

Component Compressor



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001984	UFD0000444	
Sample Date		Client Info		05 Jun 2024	06 Dec 2023	
Machine Age	hrs	Client Info		8219	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Changed	Not Changd	
Sample Status				NORMAL	NORMAL	
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	0	0	
Lead	ppm	ASTM D5185m	>25	0	0	
Copper	ppm	ASTM D5185m	>50	<1	2	
Tin	ppm	ASTM D5185m	>15	0	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	<1	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m		0	0	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m		317	342	
Zinc	ppm	ASTM D5185m		10	<1	
Sulfur	ppm	ASTM D5185m		0	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		4	5	
Potassium	ppm	ASTM D5185m	>20	<1	0	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.086	0.067	





OIL ANALYSIS REPORT


















Certificate 12367

Laboratory Sample No.

Lab Number : 06204802

: UFD0001984 Unique Number : 11072263

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 10 Jun 2024 **Tested** : 11 Jun 2024

Diagnosed

: 11 Jun 2024 - Wes Davis

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FLUID-AIRE DYNAMICS

225 SPRING LAKE DR ITASCA, IL US 60143

Contact: ED DIENER

ed.diener@fluidairedynamics.com T: (847)678-8388

Contact/Location: ED DIENER - UCFLUSCH