

OIL ANALYSIS REPORT

Area PG-46 [287528] PNEUTECH AK100016777 - NOBELUS

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




NORMAL

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001320		
Sample Date		Client Info		10 May 2024		
Machine Age	hrs	Client Info		6033		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	1		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		440		
Zinc	ppm	ASTM D5185m		41		
Sulfur	ppm	ASTM D5185m		228		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		2		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.06		



OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	t history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal		*Visual	NONE	NONE		
Precipitate		*Visual	NONE	NONE		
Silt		*Visual	NONE	NONE		
Debris		*Visual	NONE	LIGHT		
Sand/Dirt		*Visual	NONE	NONE		
Appearance		*Visual	NORML	NORML		
Odor		*Visual	NORML	NORML		
Emulsified Water		*Visual	>0.1	NEG		
Free Water		*Visual		NEG		
FLUID PROPER	TIES	method	limit/base	current	t history1	history2
Visc @ 40°C	cSt	ASTM D445		43.1		
SAMPLE IMAGE	S	method	limit/base	curren	t history1	history2
Color					no image	no image
Bottom					no image	no image
GRAPHS						
Ferrous Alloys						
2 0 5701/jew	1-		May10/24			
Non-ferrous Meta	ls					
8						
May 10/24			May10/24			
Viscosity @ 40°C			2	Acid Num	ber	
Abnormal			^{0.0}			
0+9			0.0 0.0 (mg KOH(g) 0.0 (mg KOH(g) 0.0 (mg KOH(g)	06 -		
5-			<u>الے</u> این ا)4		
Abnormal			None None)2		
5			.0.0 A Cid	10		
May10/24			May10/24	May10/24		Mav10/24
May			May	May		Mav
earCheck USA - 501 Madison Ave., Cary, NC 27513 D0001320 Received : 10 Jun 2024				FLUID-AIRE DYNAMICS 225 SPRING LAKE DF		
6204813	Tested		Jun 2024		220 01 1	ITASCA, II
1072274	Diagno		Jun 2024 - V	Ves Davis		US 60143
ND 2			_			ct: ED DIENEF
ntact Customer Serv outside of the ISO 1					ed.diener@fluidair	
fications are based of				n rule (JCGM		(847)678-8388 F:

* - Denotes test methods that a Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

To discuss this sample report,

Certificate L2367

Laboratory Sample No. Lab Number **Unique Number Test Package**

Contact/Location: ED DIENER - UCFLUSCH