

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area **PG-46** [285514] PNEUTECH AK100018460 - CALCO Component Compressor

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001211		
Sample Date		Client Info		17 May 2024		
Machine Age	hrs	Client Info		1973		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		566		
Zinc	ppm	ASTM D5185m		25		
Sulfur	ppm	ASTM D5185m		138		
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	17		
Sodium	ppm	ASTM D5185m		2		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.07		



OIL ANALYSIS REPORT

VISUAL



	VISUAL		method	limit/base	current	history1	history2	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
1	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	NONE			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
May17/24	Appearance	scalar	*Visual	NORML	NORML			
May1	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.1	NEG			
	Free Water	scalar	*Visual		NEG			
	FLUID PROPER	TIES	method	limit/base	current	history1	history2	
				minubacco		· · · · · · · · · · · · · · · · · · ·	inotory 2	
1	Visc @ 40°C	cSt	ASTM D445		47.1			
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2	
May17/24	Color					no image	no image	
	Bottom					no image	no image	
	Non-ferrous Meta	Ils		4 00 000 000 000 000 000 000 000 000 000		۲ ۲		
Laboratory Sample No. Lab Number Unique Number Test Package discuss this sample report, Denotes test methods that tements of conformity to su	: UFD0001211 : 06204830 : 11072291 : IND 2 ; contact Customer Serv are outside of the ISO 3	Rece Teste Diagr vice at 1-8 17025 sco	d : 12 Jun 2024 Nosed : 12 Jun 2024 - Wes Davis 20-237-1369.			FLUID-AIRE DYNAMIC 225 SPRING LAKE D ITASCA, I US 6014 Contact: ED DIENE ed.diener@fluidairedynamics.cor T: (847)678-838 M 106:2012) F		

Report Id: UCFLUSCH [WUSCAR] 06204830 (Generated: 06/12/2024 00:26:05) Rev: 1

Contact/Location: ED DIENER - UCFLUSCH