

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area SMART OIL 6000 HERTZ VD032785 - WESTLAKE/DIMEX

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	/IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UHK0000749		
Sample Date		Client Info		31 May 2024		
Machine Age	hrs	Client Info		3696		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	6		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m	20	0		
Phosphorus	ppm	ASTM D5185m		93		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		336		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		2		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.18		



OIL ANALYSIS REPORT



	White Metal Yellow Metal	scalar scalar	*Visual *Visual	NONE NONE	NONE NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	NONE			
4	Sand/Dirt	scalar	*Visual	NONE	NONE			
May31/24	Appearance	scalar	*Visual	NORML	NORML			
M	Odor Emulsified Water	scalar scalar	*Visual *Visual	NORML >0.1	NORML NEG			
	Free Water	scalar	*Visual	>0.1	NEG			
	FLUID PROPERT		method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445	46	50.8			
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2	
May31/24	Color					no image	no image	
	Bottom					no image	no image	
	Non-ferrous Meta	ls		May31/24				
	Viscosity @ 40°C			May31/24	Acid Number			
	0 0 0 0 0 0 0 0 0 0 0 0 0 0			(B)1020 (B)1102 0.15 (B)1102 0.	,			
	May31/24			May31/24	May31/24		40(15veM	
Laboratory Sample No. Lab Number Unique Number Test Package	: UHK0000749 : 06204837 : 11072298	Recei Teste	Madison Ave., Cary, NC 27513 HE Received : 10 Jun 2024 Tested : 12 Jun 2024 Diagnosed : 12 Jun 2024 - Sean Felton e at 1-800-237-1369. 025 scope of accreditation.			RTZ KOMPRESSOREN USA IN 3320 SERVICE S CHARLOTTE, N US 2820 Contact: WARRANT warranty@hertz-kompressoren.u T: (704)579-590		

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: WARRANTY - UCHERCHA