


OIL ANALYSIS REPORT



Sample Rating Trend



NORMAL

K

BRCM01BE (S/N GZJ00658) Biogas Engine Fluid

CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0938382	WC0760839	WC0760838
Sample Date		Client Info		07 Jun 2024	04 Jun 2024	17 May 2024
Machine Age	hrs	Client Info		77233	77169	76740
Oil Age	hrs	Client Info		23	654	225
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	SEVERE	SEVERE
CONTAMINATIO	N	method	limit/base	current	history1	history2
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method		NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		15		
Iron	ppm	ASTM D5185m	>14	2	2	4
Chromium	ppm	ASTM D5185m	>3	<1	0	<1
Nickel	ppm	ASTM D5185m		0	0	<1
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>5	2	2	4
Lead	ppm	ASTM D5185m	>8	1	<1	1
Copper	ppm	ASTM D5185m	>5	<1	<1	2
Tin	ppm	ASTM D5185m	>3	<1	 5	<u> </u>
Vanadium	ppm	ASTM D5185m		<1	<1	<1
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		18	8	14
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		11	12	17
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		34	29	26
Calcium	ppm	ASTM D5185m		1769	1910	2588
Phosphorus	ppm	ASTM D5185m		288	290	436
Zinc	ppm	ASTM D5185m		346	369	520
Sulfur	ppm	ASTM D5185m		2185	2781	4037
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>180	41	4 265	2 27
Sodium	ppm	ASTM D5185m	>20	2	1	<1
Potassium	ppm	ASTM D5185m	>20	2	4	8
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0.1	0
Nitration	Abs/cm	*ASTM D7624		5.2	6.4	5.9

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Machine Id

Wear

All component wear rates are normal.

Contamination


There is no indication of any contamination in the oil.


Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.




OIL ANALYSIS REPORT








	TION	method	limit/base	current	history1	history2
Dxidation	Abs/.1mm	*ASTM D7414		8.1	15.6	10.6
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.73	2.17	1.01
Base Number (BN)	mg KOH/g	ASTM D2896	5.4	5.29	2.83	5.61
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT	NONE
ellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
ppearance	scalar	*Visual	NORML	NORML	NORML	NORML
Ddor	scalar	*Visual	NORML	NORML	NORML	NORML
mulsified Water	scalar	*Visual		NEG	NEG	NEG
ree Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
/isc @ 100°C	cSt	ASTM D445	13.4	12.6	13.4	13.1
GRAPHS						
GNAFHS						
Iron (ppm)				Lead (ppm)		
			anna 15			
Iron (ppm)			10	Severe	Λ	
				Abnormal	M	
Iron (ppm)	~~~^	-h-c		Abnormal	M	1~~~
Iron (ppm)		2/2+ 9/24 3/24		Abnormal	423-00-00-00-00-00-00-00-00-00-00-00-00-00	924
Iron (ppm)	Dec21/23 -	Feb12/24		Severe Abnormal 2012 2012 40 2012 2012 40 2012 40 2010 40 2012 40 2012 2012 40 2012 2012 40 2012 40 2012 40 20	Nov14/23	Mar29/2/4
Iron (ppm)	Dec21/23	Feb12/24		Severe Abnormal EZZZZ/eW Chromium (p		Mar29/24
Iron (ppm)	Dec21/23	Feb1224		Abnormal Chromium (p		Mar/3/24
Iron (ppm)	Dec21/23	Feb1224 +		Abnormal Chromium (p		Mar29/24
Iron (ppm)	Dec21/23	Feb12/24		Abnomal EZIZZ/eW Chromium (p		Mar29/24
Iron (ppm)	~~~	~ ~ ~		Abnomal EZIZZ/eW Chromium (p	opm)	- -
Iron (ppm)	~~~	~ ~ ~		Abnormal EZ7727/EM Chromium (p	opm)	- -
Iron (ppm)	~~~	Feb12/24 +		Severe Abnormal Chromium (p Severe Abnormal Chromium (p Severe Abnormal Chromium (p	Nov14/23	- -
Iron (ppm)	~~~	~ ~ ~		Abnormal Chromium (p Severe Abnormal EZIZZ ^{ke} W Chromium (p Severe Abnormal EZIZZ ^{ke} W Silicon (ppm)	Nov14/23	- -
Iron (ppm)	~~~	~ ~ ~		Abnormal Chromium (p Severe Abnormal EZIZZ ^{ke} W Chromium (p Severe Abnormal EZIZZ ^{ke} W Silicon (ppm)	Nov14/23	- -
Iron (ppm)	~~~	~ ~ ~		Abnormal Chromium (p Severe Abnormal EZIZZ/leW Chromium (p Severe Abnormal EZIZZ/leW Silicon (ppm)	Nov14/23	- -
Iron (ppm)	~~~	~ ~ ~		Abnormal EZIZZ/JeW Chromium (p Severe Abnormal EZIZZ/JeW Severe Silicon (ppm)	Nov14/23	- -





DCIT

: WC0938382 Received BROWN COUNTY POWER STATION, 9427 BEYERS RD Sample No. : 10 Jun 2024 Lab Number : 06204877 Tested : 12 Jun 2024 GEORGETOWN, OH Unique Number : 11072338 Diagnosed : 12 Jun 2024 - Don Baldridge Test Package : MOB 2 (Additional Tests: pq) Contact: MITCHELL BUTLER Certificate 12367 Mitchell.Butler@edlenergy.com To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Report Id: ENEGEO [WUSCAR] 06204877 (Generated: 06/12/2024 18:08:47) Rev: 1

Laboratory

Submitted By: BRETT PONTIUS

EDL NA Recips-Brown County

Page 2 of 2

US 45121

T:

F: