


FUEL REPORT

QTS SUWANEE DC2 [17765] [QTS SUWANEE DC2] G3-5

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR)





DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets ASTM D975 specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

(8000 GAL)				May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0953854		
Sample Date		Client Info		20 May 2024		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yllow	Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445	3.0	2.59		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	64.5		
SULFUR CONTE	VT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0		
Sulfur (UVF)	ppm	ASTM D5453		15		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	175		
5% Distillation Point	°C	ASTM D86		199		
10% Distill Point	°C	ASTM D86	201	209		
15% Distillation Point	°C	ASTM D86		216		
20% Distill Point	°C	ASTM D86	216	224		
30% Distill Point	°C	ASTM D86	230	238		
40% Distill Point	°C	ASTM D86	243	251		
50% Distill Point	°C	ASTM D86	255	264		
60% Distill Point	°C	ASTM D86	267	277		
70% Distill Point	°C	ASTM D86	280	290		
80% Distill Point	°C	ASTM D86	295	304		
85% Distillation Point	°C	ASTM D86		314		
90% Distill Point	°C	ASTM D86	310	325		
95% Distillation Point	°C	ASTM D86		343		
Final Boiling Point	°C	ASTM D86	341	357		
IGNITION QUALIT	ГΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36		
Cetane Index		ASTM D4737	<40.0	48		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	< 0.1	2		
Potassium	ppm	ASTM D5185m	<0.1	1		
Water	%	ASTM D6304	< 0.05	0.004		
ppm Water	ppm	ASTM D6304	<500	40		
% Gasoline	%	*In-House	< 0.50	0.0		
9/ Pindingal	0/	*!!!	-20.0	0.0		

*In-House <20.0

0.0

% Biodiesel



FUEL REPORT







Certificate 12367

Sample No.

Lab Number : 06205276

: WC0953854

Unique Number : 11072737

Received Tested Diagnosed

: 17 Jun 2024 - Elizabeth Valachovic Test Package : DF-2 (Additional Tests: Fuel, Screen) To discuss this sample report, contact Customer Service at 1-800-237-1369.

: 17 Jun 2024

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

210 POWELL DR

SUMMERVILLE, SC US 29483 Contact: AJAY EL

Ajay@prsfuel.com T: (843)225-1777

Contact/Location: AJAY EL - PETSUM