


## **FUEL REPORT**

# QTS SUWANEE DC1 [17700] [QTS SUWANEE DC1] C6

**Diesel Fuel** 

No.2 DIESEL FUEL (ULTRALOW SULPHUF





| Reco | mr | nai | hda |
|------|----|-----|-----|

All laboratory tests indicate that this sample meets ASTM D975 specifications for No.2 low-sulfur diesel fuel.

#### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

#### **Fuel Condition**

Sulfur value derived by ASTM D5453 method for ULSD validation.

| R) (3000 GAL)              |        |                  |                | May2024     |                 |          |
|----------------------------|--------|------------------|----------------|-------------|-----------------|----------|
| CAMPLE INFORM              | MATION | un nation of     | lii.t/la.a.a.a | 2           | la i a ta un ce | histow O |
| SAMPLE INFORM              | IATION | method           | limit/base     | current     | history1        | history2 |
| Sample Number              |        | Client Info      |                | WC0953841   |                 |          |
| Sample Date                |        | Client Info      |                | 20 May 2024 |                 |          |
| Machine Age                | hrs    | Client Info      |                | 0           |                 |          |
| Sample Status              |        |                  |                | NORMAL      |                 |          |
| PHYSICAL PROP              | ERTIES | method           | limit/base     | current     | history1        | history2 |
| Fuel Color                 | text   | *Visual Screen   | Yllow          | Orange      |                 |          |
| ASTM Color                 | scalar | *ASTM D1500      |                | L4.5        |                 |          |
| Visc @ 40°C                | cSt    | ASTM D445        | 3.0            | 2.59        |                 |          |
| Pensky-Martens Flash Point | °C     | *PMCC Calculated | 52             | 62.3        |                 |          |
| SULFUR CONTE               | NΤ     | method           | limit/base     | current     | history1        | history2 |
| Sulfur                     | ppm    | ASTM D5185m      | 10             | 0           |                 |          |
| Sulfur (UVF)               | ppm    | ASTM D5453       |                | 17          |                 |          |
| DISTILLATION               |        | method           | limit/base     | current     | history1        | history2 |
| Initial Boiling Point      | °C     | ASTM D86         | 165            | 174         |                 |          |
| 5% Distillation Point      | °C     | ASTM D86         |                | 197         |                 |          |
| 10% Distill Point          | °C     | ASTM D86         | 201            | 207         |                 |          |
| 15% Distillation Point     | °C     | ASTM D86         |                | 215         |                 |          |
| 20% Distill Point          | °C     | ASTM D86         | 216            | 222         |                 |          |
| 30% Distill Point          | °C     | ASTM D86         | 230            | 237         |                 |          |
| 40% Distill Point          | °C     | ASTM D86         | 243            | 250         |                 |          |
| 50% Distill Point          | °C     | ASTM D86         | 255            | 263         |                 |          |
| 60% Distill Point          | °C     | ASTM D86         | 267            | 276         |                 |          |
| 70% Distill Point          | °C     | ASTM D86         | 280            | 289         |                 |          |
| 80% Distill Point          | °C     | ASTM D86         | 295            | 304         |                 |          |
| 85% Distillation Point     | °C     | ASTM D86         |                | 314         |                 |          |
| 90% Distill Point          | °C     | ASTM D86         | 310            | 324         |                 |          |
| 95% Distillation Point     | °C     | ASTM D86         |                | 342         |                 |          |
| Final Boiling Point        | °C     | ASTM D86         | 341            | 357         |                 |          |
| IGNITION QUALIT            | ГΥ     | method           | limit/base     | current     | history1        | history2 |
| API Gravity                |        | ASTM D7777       | 37.7           | 36          |                 |          |
| Cetane Index               |        | ASTM D4737       | <40.0          | 48          |                 |          |
| CONTAMINANTS               |        | method           | limit/base     | current     | history1        | history2 |
| Silicon                    | ppm    | ASTM D5185m      | <1.0           | 0           |                 |          |
| Sodium                     | ppm    | ASTM D5185m      | < 0.1          | 1           |                 |          |
| Potassium                  | ppm    | ASTM D5185m      | <0.1           | 1           |                 |          |
| Water                      | %      | ASTM D6304       | < 0.05         | 0.003       |                 |          |
| ppm Water                  | ppm    | ASTM D6304       | <500           | 38          |                 |          |
| % Gasoline                 | %      | *In-House        | < 0.50         | 0.0         |                 |          |
| % Biodiesel                | %      | *In-House        | <20.0          | 0.0         |                 |          |



## **FUEL REPORT**







Certificate 12367

Sample No.

: WC0953841 Lab Number : 06205277 Unique Number : 11072738

**Tested** 

Diagnosed Test Package : DF-2 (Additional Tests: Fuel, Screen)

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

To discuss this sample report, contact Customer Service at 1-800-237-1369.

210 POWELL DR SUMMERVILLE, SC US 29483

Contact: AJAY EL Ajay@prsfuel.com T: (843)225-1777

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received

: 10 Jun 2024

: 17 Jun 2024

: 17 Jun 2024 - Elizabeth Valachovic