


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AS 25T 7852912 (S/N 1630)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Nov2023	Jun2024		
SAMPLE INFORM	MATION	method				history2
Sample Number		Client Info		KCPA012552	KCPA006960	
Sample Date		Client Info		06 Jun 2024	08 Nov 2023	
Machine Age	hrs	Client Info		23679	19126	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Not Changd	N/A	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	8	1	
Tin	ppm	ASTM D5185m	>10	0	<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	100	0	<1	
Calcium	ppm	ASTM D5185m	0	0	1	
Phosphorus	ppm	ASTM D5185m	0	0	1	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	23500	18128	8413	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		2	0	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.006	0.006	
ppm Water	ppm	ASTM D6304	>500	68	60.8	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1073	7824	
Particles >6µm		ASTM D7647	>1300	322	<u>▲</u> 3461	
Particles >14μm		ASTM D7647	>80	11	△ 375	
Particles >21µm		ASTM D7647	>20	2	△ 92	
Particles >38μm		ASTM D7647	>4	0	3	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>17/13	16/11	<u> </u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.49	0.43	



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No. Lab Number

: KCPA012552 : 06205420 Unique Number : 11072881

Received : 10 Jun 2024 **Tested** Diagnosed

: 13 Jun 2024 : 13 Jun 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

69 DODGE AVE NORTH HAVEN, CT US 06473 Contact: ADAM adam@jamesmfg.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: