


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# **KAESER 1188645**

Component Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

### **DIAGNOSIS**

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		L	Feb 2023	Jun2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018901	KCP000318	
Sample Date		Client Info		05 Jun 2024	27 Feb 2023	
Machine Age	hrs	Client Info		14070	24071	
Oil Age	hrs	Client Info		0	0	
Oil Changed	1113	Client Info		Changed	N/A	
Sample Status		Olletti IIIIO		ABNORMAL	ABNORMAL	
				ADNOMNAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	8	13	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	100	18	8	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	0	<1	
Zinc	ppm	ASTM D5185m	0	28	41	
Sulfur	ppm	ASTM D5185m	23500	21961	17732	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	1	
Sodium	ppm	ASTM D5185m		5	2	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.013	0.003	
ppm Water	ppm	ASTM D6304	>500	131	35.4	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		7799	34094	
Particles >6µm		ASTM D7647	>1300	<b>4</b> 2405	<b>△</b> 7936	
Particles >14µm		ASTM D7647	>80	<u> </u>	150	
Particles >21µm		ASTM D7647	>20	<u>^</u> 71	9	
Particles >38µm		ASTM D7647	>4	<u>^</u> 8	0	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/18/15</b>	<u>22/20/14</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.39	0.39	



## **OIL ANALYSIS REPORT**







Lab Number

Laboratory Sample No.

: KCPA018901 : 06205433 Unique Number : 11072894

Received Tested

: 13 Jun 2024 Diagnosed

: 10 Jun 2024 : 13 Jun 2024 - Don Baldridge

AT COMPONENTS 467 HEIN DR GARNER, NC US 27529 Contact: Service Manager

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: