


PROBLEM SUMMARY

Sample Rating Trend




Machine Id


LEROI 111448 - LP1 (S/N SC354528)

Compressor

CIMARRON HB-150 (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

PROBLEMATIC TEST RESULTS									
Sample Status				SEVERE	ABNORMAL				
Tin	ppm	ASTM D5185m	>3	<u> </u>	<1				
Water	%	ASTM D6304	>2.26	27.9	△ 0.985				
ppm Water	ppm	ASTM D6304	>22600	279000	<u></u> 9850				
Emulsified Water	scalar	*Visual	>2.26	0.2%	NEG				

Customer Id: CIMCAR Sample No.: TO90004071 Lab Number: 06205571 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	Oil and filter change at the time of sampling has been noted.		
Change Filter			?	Oil and filter change at the time of sampling has been noted.		
Resample			?	We recommend an early resample to monitor this condition.		

HISTORICAL DIAGNOSIS




01 May 2024 Diag: Angela Borella
We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

LEROI 111448 - LP1 (S/N SC354528)

Compressor

CIMARRON HB-150 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

All component wear rates are normal.

Contamination

Appearance is hazy. There is a high concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

			May2024	May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO90004071	TO90004232	
Sample Date		Client Info		24 May 2024	01 May 2024	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Changed	N/A	
Sample Status				SEVERE	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>70	0	4	
Chromium	ppm	ASTM D5185m	>10	0	<1	
Nickel	ppm	ASTM D5185m		<1	<1	
Titanium	ppm	ASTM D5185m		0	<1	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>3	1	2	
Lead	ppm	ASTM D5185m	>4	<1	0	
Copper	ppm	ASTM D5185m	>20	0	<1	
Tin	ppm	ASTM D5185m	>3	<u>^</u> 3	<1	
Vanadium	ppm	ASTM D5185m		<1	<1	
Cadmium	ppm	ASTM D5185m		<1	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	11	0	
Barium	ppm	ASTM D5185m	0	0	1	
Molybdenum	ppm	ASTM D5185m	0	0	<1	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	0	3	<1	
Calcium	ppm	ASTM D5185m	0	15	5	
Phosphorus	ppm	ASTM D5185m	0	34	14	
Zinc	ppm	ASTM D5185m	0	10	3	
Sulfur	ppm	ASTM D5185m	0	635	173	
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>45	2	1	
Sodium	ppm	ASTM D5185m		0	1	
Potassium	ppm	ASTM D5185m	>20	5	<1	
Water	%	ASTM D6304	>2.26	27.9	△ 0.985	
ppm Water	ppm	ASTM D6304	>22600	279000	△ 9850	
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000		5929	
Particles >6µm		ASTM D7647	>2500		1076	
Particles >14µm		ASTM D7647	>320		44	
Particles >21µm		ASTM D7647	>80		10	
Particles >38µm		ASTM D7647	>20		2	
Particles >71µm		ASTM D7647	>4		1	
Oil Cleanliness		ISO 4406 (c)	>20/18/15		20/17/13	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (ANI)	ma 1/011/a	ACTM DODAE		0.10	0.076	

Acid Number (AN)


mg KOH/g ASTM D8045

0.076

0.12



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No. Lab Number

: TO90004071 : 06205571 Unique Number : 11073032

Received : 10 Jun 2024 **Tested** : 18 Jun 2024 Diagnosed

: 18 Jun 2024 - Jonathan Hester Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CIMARRON ENERGY - CARLSBAD

4425 GRANDI RD, UNIT F CARLSBAD, NM UM 88220-8923 Contact: CARLOS LEAL

cleal@cimarron.com T:

Contact/Location: CARLOS LEAL - CIMCAR

F: